

Industrial, commercial and garage doors and gates — Air permeability — Test method

The European Standard EN 12427:2000 has the status of a
British Standard

ICS 91.060.50

National foreword

This British Standard is the official English language version of EN 12427:2000.

The UK participation in its preparation was entrusted by Technical Committee B/538, Doors, windows, shutters, hardware and curtain walling, to Subcommittee B/538/5, Industrial, commercial and garage doors and gates, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the BSI Standards Catalogue under the section entitled "International Standards Correspondence Index", or by using the "Find" facility of the BSI Standards Electronic Catalogue.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 7 and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

Amendments issued since publication

Amd. No.	Date	Comments

This British Standard, having been prepared under the direction of the Sector Committee for Building and Civil Engineering, was published under the authority of the Standards Committee and comes into effect on 15 October 2000

© BSI 10-2000

ISBN 0 580 36539 5

EUROPEAN STANDARD

EN 12427

NORME EUROPÉENNE

EUROPÄISCHE NORM

July 2000

ICS 91.060.50

English version

Industrial, commercial and garage doors and gates - Air permeability - Test method

Portes équipant les locaux industriels, commerciaux et les garages - Perméabilité à l'air - Méthode d'essai

Tore - Luftdurchlässigkeit - Prüfverfahren

This European Standard was approved by CEN on 19 July 2000.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Central Secretariat: rue de Stassart, 36 B-1050 Brussels

Contents

	Page
Foreword	2
1 Scope	3
2 Normative References	3
3 Terms and definitions	4
4 Principle of test	4
5 Apparatus	4
6 Preparation of test specimen	4
7 Test procedure	5
8 Test report	6
Annex A (normative) Air pressure sequence for test rig	7

Foreword

This European Standard has been prepared by Technical Committee CEN/TC 33 " Doors, windows, shutters, building hardware and curtain walling", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2001, and conflicting national standards shall be withdrawn at the latest by January 2001.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

No existing EN standard is superseded.

This standard is one of a series of test standards identified within the product standard prEN 13 241:1998.

European Standards as well as relevant national regulations and standards will enable the actual exposure levels to be determined for the individual locations of the products.

Annex A is normative.

This standard has been drafted on basis of EN 12114 "Thermal performance of building – Air permeability of building components and building elements – Laboratory test method".

1 Scope

1.1 General

This European Standard specifies a test method for determining the air permeability for doors in a closed position.

The doors are intended for installation in areas in the reach of people, for which the main intended uses are giving safe access for goods, vehicles and persons in industrial, commercial or residential premises.

The doors may be manually or power operated.

This document applies to all doors provided in accordance with prEN 13 241:1998.

1.2 Exclusions

It does not apply to:

- lock gates and dock gates;
- doors on lifts;
- doors on vehicles;
- armoured doors;
- doors mainly for the retention of animals;
- theatre textile curtains;
- horizontally moving doors less than 2,5 m wide and 6,25 m² area, designed principally for pedestrian use;
- revolving doors of any size;
- doors outside the reach of people (such as crane gantry fences);
- railway barriers;
- barriers used solely for vehicles.

2 Normative References

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies.

EN 12 433-1	Industrial, commercial and garage doors and gates - Terminology - Part 1: Types of doors
EN 12 433-2	Industrial, commercial and garage doors and gates - Terminology - Part 2: Parts of doors
EN 12 426	Industrial, commercial and garage doors and gates – Air permeability - Classification

3 Terms and definitions

For the purpose of this standard the terms and definitions in EN 12 433-1 and EN 12 433-2 apply. In addition the following definitions also apply:

- 3.1** Air permeability: ability of a test specimen in relation to the overall area, when in closed position, to allow air flow, expressed in $\text{m}^3/\text{m}^2 \text{ h}$.
- 3.2** Overall area: the area of the structural opening of the specimen, expressed in square meters (m^2).

4 Principle of test

Application of air pressure (positive or negative) on the external or internal surface of the test specimen whilst a measurement of the airflow is made with a device according to 5 c).

5 Apparatus

The basic test apparatus shall include:

- a) an opening to which the test specimen can be fitted, to simulate the structural opening of the product on site.
- b) device(s) to provide controlled air pressure, above atmospheric air pressure, to the exposed surface of the specimen.
- c) device(s) to measure the amount of airflow with an accuracy of $\pm 5\%$. It shall be calibrated so as to give airflow in normal conditions (20°C , 101 kPa).
- d) device(s) for measuring air pressure with an accuracy of $\pm 5\%$.
- e) a means of sealing all joints of the specimen when required.

NOTE The test rig should not be designed to increase the performance of the specimen.

The test rig shall be prepared so that it is able to withstand the pressures applied during the test, without deflecting to an extent likely to impair jointing or to impose bending stresses.

6 Preparation of test specimen

- a) The test specimen shall be installed in accordance with the manufacturer's standard or published installation instructions.
- b) The test specimen shall consist of parts, which in detail conform to the production level of quality. Whenever possible the test specimen should be newly made. Doors and parts in stock are to be regarded as newly made if they fully comply with the specification of the running production.

- c) The test specimen shall be clean and the surfaces dry.
- d) Any ventilation, drainage or "weep holes" shall be taped up or left open according to the purpose of test and this purpose and state shall be noted and recorded. In most cases, air can pass through both fixed and opening joints.
- e) Minimum dimensions of specimen see table 1.

Table 1 - Minimum dimensions of specimen

Commercial and garage doors	Width: 2 000 mm Height: 2 000 mm
Industrial doors	Width: 3 500 mm Height: 3 000 mm

7 Test procedure

7.1 Preliminaries

The test specimen shall be conditioned for at least 4 h within the range 10°C to 30°C and 25% to 75% relative humidities immediately before testing.

Temperature shall be measured within $\pm 3^\circ\text{C}$.

Atmospheric pressure shall be measured within ± 1 kPa.

The pressure shall be applied up to 50 Pa.

7.2 Procedure

The residual air permeability shall be measured prior to the specimen test.

The diagrams of pressure sequences given in Annex A may be helpful for a clear understanding.

7.2.1 Air permeability with positive pressure shall be carried out first.

Negative pressure shall be carried out only if required.

7.2.2 Air permeability of specimen fitted to the test rig shall be measured.

7.2.3 The test specimen shall be opened and closed at least once before finally secured in the closed position.

7.2.4 Apply three air pressure pulses, to position the seals, the rate of application being over a period of not less than one second. Maintain each pulse for at least three seconds.

These pulses shall produce a pressure 10% greater than the maximum pressure P_{\max} required for the test.

7.2.5 The air pressure in the test rig is then raised up to 50 Pa.

The duration should be such that air pressure in the test rig is adequately stabilised before reading the value linked to air permeability.

7.2.6 Calculate the air permeability according to the formula:

$$\frac{\text{Air leakage (m}^3/\text{h)} - \text{Residual air leakage (m}^3/\text{h)}}{\text{Structural opening (m}^2\text{)}}$$

8 Test report


The test report shall state the devices used for the test and also record the location of any air leakage observed, on a drawing or a photograph of the test specimen.

The report shall contain as a minimum the following information:

- a) date of the test report;
- b) reference to this standard;
- c) name of the approved laboratory, if applicable;
- d) all necessary references to identify the specimen;
- e) all relevant details concerning the dimensions of the specimen, its materials, design, construction and manufacture and its finished surface and fittings and also its method of delivery;
- f) drawings of details of the specimen shall be of a suitable scale;
- g) identification of the test equipment;
- h) test method;
- i) test procedures, including storage and conditioning prior to test and mounting the specimen ready for test;
- j) test climates used;
- k) location of air leakage, if detectable;
- l) take the overall area (m²) into account when to calculate the specific airflow in m³/ m²h (see 3.2);
- m) air permeability result;
- n) summary with observations;
- o) determine the classification according to EN 12 426;
- p) signature of the responsible person.

Annex A (normative)

Air pressure sequence for test rig



Key

-  Opening and closing operation
- 1 Stabilized pressure

BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover. Tel: 020 8996 9000. Fax: 020 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: 020 8996 9001. Fax: 020 8996 7001.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre. Tel: 020 8996 7111. Fax: 020 8996 7048.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration. Tel: 020 8996 7002. Fax: 020 8996 7001.

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

If permission is granted, the terms may include royalty payments or a licensing agreement. Details and advice can be obtained from the Copyright Manager. Tel: 020 8996 7070.