

UL 486E

Equipment Wiring Terminals
for Use with Aluminum and/or
Copper Conductors

Underwriters Laboratories Inc. (UL)
333 Pfingsten Road
Northbrook, IL 60062-2096

UL Standard for Safety for Equipment Wiring Terminals for Use with Aluminum and/or Copper Conductors, UL 486E

Fourth Edition, Dated May 7, 2009

Summary of Topics

This new edition of ANSI/UL 486E covers equipment wiring terminals for use with all alloys of copper, aluminum, or copper-clad aluminum conductors and has been reformatted to match the presentation of the other UL 486 series of standards.

UL Standards for Safety are developed and maintained in the Standard Generalized Markup Language (SGML). SGML -- an international standard (ISO 8879-1986) -- is a descriptive markup language that describes a document's structure and purpose, rather than its physical appearance on a page. Due to formatting differences resulting from the use of UL's new electronic publishing system, please note that additional pages (on which no requirements have been changed) may be included in revision pages due to relocation of existing text and reformatting of the Standard.

The new and revised requirements are substantially in accordance with UL's Proposal(s) on this subject dated February 20, 2009.

As indicated on the title page (page 1), this UL Standard for Safety is an American National Standard. Attention is directed to the note on the title page of this Standard outlining the procedures to be followed to retain the approved text of this ANSI/UL Standard.

The UL Foreword is no longer located within the UL Standard. For information concerning the use and application of the requirements contained in this Standard, the current version of the UL Foreword is located on ULStandardsInfoNet at: <http://ulstandardsinfo.net/ulforeword.html>

The master for this Standard at UL's Northbrook Office is the official document insofar as it relates to a UL service and the compliance of a product with respect to the requirements for that product and service, or if there are questions regarding the accuracy of this Standard.

UL's Standards for Safety are copyrighted by UL. Neither a printed copy of a Standard, nor the distribution diskette for a Standard-on-Diskette and the file for the Standard on the distribution diskette should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

Revisions of UL Standards for Safety are issued from time to time. A UL Standard for Safety is current only if it incorporates the most recently adopted revisions.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

UL will attempt to answer support requests concerning electronic versions of its Standards. However, this support service is offered on a reasonable efforts basis only, and UL may not be able to resolve every support request. UL supports the electronic versions of its Standards only if they are used under the conditions and operating systems for which it is intended. UL's support policies may change from time-to-time without notification.

UL reserves the right to change the format, presentation, file types and formats, delivery methods and formats, and the like of both its printed and electronic Standards without prior notice.

Purchasers of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgement (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

If a single-user version electronic Standard was purchased, one copy of this Standard may be stored on the hard disk of a single personal computer, or on a single LAN file-server or the permanent storage device of a multiple-user computer in such a manner that this Standard may only be accessed by one user at a time and for which there is no possibility of multiple concurrent access.

If a multiple-user version electronic Standard was purchased, one copy of the Standard may be stored on a single LAN file-server, or on the permanent storage device of a multiple-user computer, or on an Intranet server. The number of concurrent users shall not exceed the number of users authorized.

Electronic Standards are intended for on-line use, such as for viewing the requirements of a Standard, conducting a word search, and the like. Only one copy of the Standard may be printed from each single-user version of an electronic Standard. Only one copy of the Standard may be printed for each authorized user of a multiple-user version of an electronic Standard. Because of differences in the computer/software/printer setup used by UL and those of electronic Standards purchasers, the printed copy obtained by a purchaser may not look exactly like the on-line screen view or the printed Standard.

An employee of an organization purchasing a UL Standard can make a copy of the page or pages being viewed for their own fair and/or practical internal use.

The requirements in this Standard are now in effect, except for those paragraphs, sections, tables, figures, and/or other elements of the Standard having future effective dates as indicated in the note following the affected item. The prior text for requirements that have been revised and that have a future effective date are located after the Standard, and are preceded by a "SUPERSEDED REQUIREMENTS" notice.

New product submittals made prior to a specified future effective date will be judged under all of the requirements in this Standard including those requirements with a specified future effective date, unless the applicant specifically requests that the product be judged under the current requirements. However, if the applicant elects this option, it should be noted that compliance with all the requirements in this Standard will be required as a condition of continued Listing, Recognition, and Follow-Up Services after the effective date, and understanding of this should be signified in writing.

This Standard consists of pages dated as shown in the following checklist:

Page	Date
1-46	May 7, 2009
A1-A2	May 7, 2009
B1-B2	May 7, 2009
C1-C2	May 7, 2009
D1-D2	May 7, 2009

No Text on This Page

MAY 7, 2009



ANSI/UL 486E-2009

1

UL 486E

**Standard for Equipment Wiring Terminals for Use with Aluminum and/or
Copper Conductors**

First Edition – August, 1984
Second Edition – May, 1988
Third Edition – December, 1994

Fourth Edition

May 7, 2009

This ANSI/UL Standard for Safety consists of the Fourth Edition.

The most recent designation of ANSI/UL 486E as an American National Standard (ANSI) occurred on May 7, 2009. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page, or effective date information.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <http://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2009 UNDERWRITERS LABORATORIES INC.

No Text on This Page

CONTENTS

1	Scope	4
2	Reference Publications	5
2.1	Normative references	5
2.2	Informative references	5
3	Units of Measurement	5
4	Definitions	6
5	Symbols and Abbreviations	6
6	Construction Requirements	8
6.1	General	8
6.2	Materials	9
7	Test Requirements	9
7.1	General	9
7.2	Current-cycling	11
7.3	Static-heating sequence	12
7.4	Mechanical sequence	12
7.5	Stress corrosion/moist ammonia (NH ₄)	13
7.6	Stress corrosion/mercurous nitrate (HgNO ₃)	13
8	Sampling Requirements	13
8.1	General	13
8.2	Current-cycling	14
8.3	Static-heating sequence	16
8.4	Mechanical sequence	16
8.5	Stress corrosion/moist ammonia (NH ₄)	17
8.6	Stress corrosion/mercurous nitrate (HgNO ₃)	17
9	Test Methods	17
9.1	General	17
9.2	Current-cycling	25
9.3	Static-heating sequence	26
9.4	Mechanical sequence	27
9.5	Stress corrosion/moist ammonia (NH ₄)	27
9.6	Stress corrosion/mercurous nitrate (HgNO ₃)	28
10	Marking, Labeling, and Packaging	28

ANNEX A – Informative References

ANNEX B – Examples

B.1	Examples from Clause 7.1.4	B1
B.2	Example from Clause 8.3.2 (ampere-rated, non-parallel)	B1
B.3	Example from Clause 8.3.3 (ampere-rated, both parallel and non-parallel)	B2

ANNEX C – Stability Factor Calculation

ANNEX D – Marking Locations Guide

1 Scope

1.1 This Standard applies to equipment wiring terminals for use with all alloys of copper, aluminum, or copper-clad aluminum conductors, in accordance with the National Electrical Code, ANSI/NFPA 70, as follows:

- a) equipment wiring terminals intended to hold one or more conductor(s);
- b) equipment wiring terminals intended for use in appliances and equipment that comply with the requirements for such appliances and equipment;
- c) ampere-rated equipment wiring terminals;
- d) horsepower rated equipment wiring terminals; and
- e) wire range rated equipment wiring terminals.

1.2 These requirements apply to field wired equipment wiring terminals which are an integral part of the equipment, or are intended for use in specific equipment.

1.3 This Standard is intended for equipment wiring terminals suitable for use with conductors in the size ranges as follows:

a) Aluminum

- 1) 12 AWG (3.3 mm²) and 10 AWG (5.3 mm²) solid; and
- 2) 12 AWG (3.3 mm²) to 2 000 kcmil (1 010 mm²) stranded, Class B concentric, compressed, and compact.

b) Copper-Clad Aluminum

- 1) 12 AWG (3.3 mm²) and 10 AWG (5.3 mm²) solid; and
- 2) 12 AWG (3.3 mm²) to 2 000 kcmil (1 010 mm²) stranded, Class B concentric.

c) Copper

- 1) 30 AWG (0.05 mm²) to 10 AWG (5.3 mm²) solid; and
- 2) 30 AWG (0.05 mm²) to 2 000 kcmil (1 010 mm²) stranded, Class B concentric and compressed, and Class C concentric.

d) Compact-stranded copper conductors for 2 AWG (33.6 mm²) and larger.

e) Rigid (solid and stranded) metric wire falling within the ranges of the above AWG sizes.

Note: For example, an equipment wiring terminal rated for 6 AWG – 250 kcmil may be additionally rated for 16 – 120 mm².

f) Other class and strand configurations as indicated by marking.

1.4 This Standard is intended for equipment wiring terminals suitable for currents not exceeding the ampacity of insulated conductors rated 75°C or 90°C in accordance with the rating of the equipment wiring terminal, if provided.

1.5 This Standard does not apply to:

- a) insulated equipment wiring terminals; and
- b) wire binding screw terminals.

2 Reference Publications

2.1 Normative references

2.1.1 For undated references to Standards, such reference shall be considered to refer to the latest edition and all revisions to that edition up to the time when this Standard was approved. For dated references to Standards, such reference shall be considered to refer to the dated edition and all revisions published to that edition up to the time the Standard was approved.

2.1.2 NFPA* Standard

ANSI/NFPA 70-2005,

National Electrical Code (NEC)

*National Fire Protection Association

2.2 Informative references

2.2.1 See Annex A for a listing of supplemental standards.

3 Units of Measurement

3.1 The values given in SI (metric) units shall be normative, except for AWG/kcmil conductor sizes. Any other values are for information only.

4 Definitions

4.1 For the purpose of this Standard, the following terms and definitions apply.

4.2 circular mil (cmil) – the area of a circle with a diameter of 0.001 inch.

4.3 control conductor – an unbroken conductor, which is included in the current-cycling test loop.

4.4 crimping die – that part of a crimping tool which forms the crimp(s) and usually incorporates the crimp anvil(s), the crimp indenter(s), and the positioner.

Note: Crimping dies may have separate or integral sections for compressing the insulation grip, if provided.

4.5 equalizer – a busbar that provides a point of equipotential and uniform current flow in a stranded conductor without adversely affecting the temperature of the equipment wiring terminal(s).

4.6 equipment wiring terminal – establishes a connection between one or more conductors to a terminal plate or stud, or to any similar device, by means of mechanical pressure.

4.7 packaging container – the container in which the unit containers are packaged.

4.8 rated current (ampere rating) – current assigned to the equipment wiring terminal by the manufacturer.

4.9 stability factor S – the measure of temperature stability of a equipment wiring terminal during the current-cycling test.

4.10 temperature rise – denotes the difference of the temperature of the equipment wiring terminal, measured under load, and the ambient temperature.

4.11 unit container – the smallest container in which equipment wiring terminals are packaged.

5 Symbols and Abbreviations

5.1 ° – Degree

5.2 A – Amps, Amperes

5.3 Al – Aluminum

5.4 AWG – American Wire Gage/gauge

5.5 C – Celsius

5.6 CC – Copper-Clad Aluminum

5.7 Cu – Copper

5.8 d – Days

5.9 f – Flexible

5.10 h – Hours

5.11 HgNO_3 – Mercurous nitrate

5.12 Hz – Hertz, cycles per second

5.13 in – Inch, Inches

5.14 kcmil – Thousand circular mil

5.15 m – Meter

5.16 mil – Thousandth of an inch

5.17 min – Minutes

5.18 ml – Milliliter

5.19 mm – Millimeter

5.20 mm^2 – Square millimeter

5.21 N – Newton - kilogram meter/sec²

5.22 NH_4 – Ammonia

5.23 r – Rigid solid and rigid stranded

5.24 rpm – Revolutions per minute

5.25 s – Seconds

5.26 SAE – Society of Automotive Engineers

5.27 sol – Solid

5.28 str – Stranded

5.29 V – Volts

6 Construction Requirements

6.1 General

6.1.1 The design and construction of an equipment wiring terminal intended for use with stranded conductors shall be such that all strands of the conductor shall be contained within the equipment wiring terminal.

6.1.2 An equipment wiring terminal that is suitable for compact-stranded conductors shall also accept all strands of a Class B concentric-stranded conductor of the same size.

6.1.3 An equipment wiring terminal intended for use with conductors of different sizes shall have a clamping mechanism that adapts to conductors of different sizes without permanent removal or addition of parts. Some examples of clamping mechanisms are:

- a) direct bearing screws with or without use of a pressure plate;
- b) a pressure plate or plates and a screw or screws;
- c) deformation of the equipment wiring terminal barrel (crimping) using a special tool;
- d) a spring pressure terminal; and
- e) an element for insulation-piercing or displacement.

6.1.4 Any rearrangement or adjustment of an equipment wiring terminal that is necessary to adapt it to various sizes of conductors shall be obvious unless the equipment wiring terminal is marked as described in 10.11.

6.1.5 There shall be no sharp edges or corners on the outer surface of an equipment wiring terminal that result in damage to insulation that the equipment wiring terminal contacts.

6.1.6 The construction of an equipment wiring terminal intended to secure more than a single conductor shall be such that there will be no intermixing (direct conductor contact) between the conductors of different materials unless the equipment wiring terminal is investigated and found to meet the performance requirements of this Standard and is marked in accordance with 10.20.

6.1.7 If the method of mounting an equipment wiring terminal is such that the mounting means cannot be retightened after wires are installed, or after the equipment wiring terminal is mounted in equipment, the mounting means – by inherent features or manufacturer's specifications – shall limit rotation of the terminal around its mounting means to 30 degrees or less.

6.2 Materials

6.2.1 The main current-carrying part of an equipment wiring terminal shall be of aluminum, an aluminum alloy, copper, a copper alloy, or other material investigated and found to meet the performance requirements of this Standard.

6.2.2 The main current-carrying part of an equipment wiring terminal may be of plated steel or unplated steel of a corrosion resistant alloy if the equipment wiring terminal complies with the requirements for the end product.

6.2.3 An equipment wiring terminal intended for use with aluminum conductor(s) or an equipment wiring terminal body of aluminum or aluminum alloy shall be coated with an electrically conductive coating, such as tin, that will inhibit oxidation and corrosion. The following need not be coated:

- a) the wire-securing (barrel) portion of an equipment wiring terminal that is shipped prefilled with an oxide-inhibiting compound;
- b) the top cap of a lay-in equipment wiring terminal not in contact with the wire; and
- c) the stamped mounting hole in an equipment wiring terminal that is intended to be secured by a bolt, nut, and washer.

Note: Other coatings may be used if investigated for the purpose and found suitable.

6.2.4 Iron or steel, if protected against corrosion, may be used for screws, plates, yokes, or other parts that are employed as a means of clamping the conductor, if such parts are not the primary current-carrying members.

6.2.5 In regards to 6.2.4, an equipment wiring terminal intended for use in an appliance or equipment that complies with the requirements for such appliance or equipment may be plated steel or unplated steel of a corrosion-resistant alloy.

7 Test Requirements

7.1 General

7.1.1 An equipment wiring terminal shall meet the test requirements when separate sets of specimens are subjected to the applicable tests for the design of the equipment wiring terminal as specified in Table 1 through Table 2 and in 7.5 through 7.6.

7.1.2 With reference to 7.1.1, an equipment wiring terminal of copper or copper alloy need not be subjected to the current-cycling sequence using copper conductor, unless the equipment wiring terminal is dependent upon insulation piercing, insulation displacement, or spring action.

7.1.3 With reference to 7.1.1, the initial static-heating test need not be conducted in the static-heating sequence using copper conductor.

7.1.4 With reference to 7.1.1, for other than a tool-applied crimp type equipment wiring terminal, the current-cycling test using a copper conductor need not be performed when the equipment wiring terminal has been current-cycling tested with an aluminum conductor of a size not smaller than the size of the copper conductor required for the current-cycling test.

Note: See Annex B for example.

7.1.5 Conductor sizes 30 – 20 AWG (0.05 – 0.52 mm²) need not be subjected to the secureness test in the static-heating sequence or mechanical sequence.

7.1.6 Specimen sets shall be subjected to the test sequences using the conductor material specified in Table 3 for the one or more conductor material combinations for which the equipment wiring terminal is intended. The stress corrosion tests shall be permitted to be conducted using either copper or aluminum conductor. When an equipment wiring terminal is rated for copper-to-copper, aluminum-to-aluminum, and copper-to-aluminum (intermixed), the mechanical sequence with copper-to-aluminum conductors may be omitted.

7.1.7 For an equipment wiring terminal intended to be used with aluminum, copper-clad aluminum, and copper wire (marked "AL-CU" on the equipment wiring terminal or the end use equipment), sample sets with aluminum wire and copper wire are to be subjected to the test sequence in Table 1 or Table 2. For an equipment wiring terminal intended to be used with copper-clad aluminum wire and copper wire (marked "CC-CU" on the equipment wiring terminal or the end use equipment), sample sets with copper-clad aluminum wire and copper wire are to be subjected to the test sequence in Table 1 or Table 2. For a terminal intended to be used with copper wire only, sample sets with copper wire are to be subjected to the test sequence in Table 1 or Table 2.

7.1.8 Tests with aluminum wire are representative of tests with copper-clad aluminum wire.

7.1.9 An equipment wiring terminal rated for Class 5 and 6 metric conductors (flexible stranded) shall be subjected to all test sequences using flexible metric conductors.

7.1.10 For an equipment wiring terminal intended to be used with aluminum and copper conductor, specimens with aluminum conductor and copper conductor shall be subjected to the current-cycling, static-heating sequence, and mechanical sequence tests.

7.1.11 For an aluminum-bodied equipment wiring terminal intended to be used with copper conductor only, specimens with copper conductor shall be subjected to the current-cycling, static-heating sequence, and mechanical sequence tests.

7.1.12 Tests conducted on an equipment wiring terminal with compact-stranded conductors shall represent tests with concentric and compressed stranded conductors of the same size.

7.1.13 The mechanical sequence and static sequence tests are to be conducted on the equipment wiring terminals in the end use equipment of which they are an integral part. The static heating test of the static sequence tests may be conducted on a sample not subjected to the Secureness Test. See 7.3.2.

7.1.14 In regards to 7.1.13, with the concurrence of those concerned, all test sequences may be conducted on samples prepared in accordance with 9.1.8 if such preparation is representative of the final use of the equipment wiring terminals in the end use equipment. See 9.1.8.8 for additional requirements for tangleless type equipment wiring terminals.

7.1.15 In regards to 7.1.13, equipment wiring terminals may be removed from the end use equipment if interference from molded parts, or the enclosure walls, or both, may occur.

7.1.16 In regards to 7.1.13, equipment wiring terminals that are intended for use in specific end use equipment but are not integral to the end use equipment may be tested in free air outside the end use equipment.

7.1.17 The current-cycling tests are to be conducted on equipment wiring terminals that have been assembled utilizing the enclosure in the end use equipment or a reasonable facsimile and then removed and tested in open air.

7.2 Current-cycling

7.2.1 The specimen sets shall complete 500 cycles of equal current-on and current-off operations for the periods of time specified in Table 4, other than as noted in 9.2.1 and 9.2.4, while carrying the current specified for the equipment wiring terminal temperature rating and conductor size being tested.

7.2.2 The current-cycling test shall be completed without any equipment wiring terminal exceeding a 125°C temperature rise above the ambient temperature for any recorded cycle.

7.2.3 The stability factor " S_i " (see 7.2.4) shall not exceed ± 10 for the equipment wiring terminal temperature measurements taken at approximately 25, 50, 75, 100, 125, 175, 225, 275, 350, 425, and 500 cycles.

7.2.4 The stability factor " S_i " for each of the 11 temperature measurements shall be determined by applying the following equations:

$$S_i = d_i - D$$

$$D = [d_1 + d_2 + \dots + d_{11}]/11$$

in which:

D is the average temperature deviation,

i is a number from 1 to 11 and signifies one of the 11 individual temperature measurements,
and

d_i is a temperature deviation for an individual temperature measurement.

Note: The value for d_i is determined by subtracting the control conductor temperature from the equipment wiring terminal temperature. The value for d_i is a positive number when the equipment wiring terminal temperature is more than that of the control conductor and a negative number when the equipment wiring terminal temperature is less than that of the control conductor. The average of the 11 temperature deviations is then determined. See Annex C for example.

7.3 Static-heating sequence

7.3.1 The specimen sets shall carry continuously the value of 60 Hz test current specified in Table 4 or Table 5 for the conductor size being tested until stable temperatures are reached without exceeding a 50°C temperature rise above ambient temperature.

Note 1: The temperature rise on an ampere-rated equipment wiring terminal may exceed 50°C when the equipment wiring terminal, as used in the intended end use equipment application, does not exceed the maximum allowable temperature rise permitted for the end-use equipment application.

Note 2: A current source may be maintained at or above the required value by regulation or frequent adjustment.

7.3.2 For equipment wiring terminals which are tested as part of the end use equipment, see 7.1.13, the samples shall carry the rated current of the end use equipment without exceeding the temperature limits for that particular equipment.

7.3.3 The joint between an equipment wiring terminal and the conductor shall be intact after being subjected for 15 min to the secureness test described in 9.3.2.

7.3.4 The joint between an equipment wiring terminal and the conductor of a specimen set shall be intact after being subjected for 1 min to the pullout test described in 9.3.4.

7.3.5 As a result of the tests, there shall be no breakage of the conductor or any strand of a stranded conductor, stripping of threads, shearing of parts, or other damage to the equipment wiring terminal. Breaking of the conductor or any strand of a stranded conductor shall be determined by examination of the complete equipment wiring terminal assembly while still intact after the secureness or pullout tests. Breakage has occurred if the conductor or a strand of a stranded conductor becomes visibly unattached. Strand breakage of 5 percent is allowed for flexible and fine stranded conductors.

7.4 Mechanical sequence

7.4.1 The joint between an equipment wiring terminal and the conductor of a specimen set shall be intact after being subjected for 30 min to the secureness test described in 9.3.2.

7.4.2 The joint between an equipment wiring terminal and the conductor of a specimen set shall be intact after being subjected for 1 min to the pullout test described in 9.3.4.

7.4.3 As a result of the tests, there shall be no breakage of the conductor or any strand of a stranded conductor, stripping of threads, shearing of parts, or other damage to the equipment wiring terminal. Breaking of the conductor or any strand of a stranded conductor shall be determined by examination of the complete equipment wiring terminal assembly while still intact after the secureness or pullout tests. Breakage has occurred if the conductor or a strand of a stranded conductor becomes visibly unattached. Strand breakage of 5 percent is allowed for flexible and fine stranded conductors.

7.5 Stress corrosion/moist ammonia (NH₄)

7.5.1 A copper alloy part of an equipment wiring terminal shall be resistant to stress corrosion cracking.

Note: The moist ammonia test is considered an alternative to the mercurous nitrate test.

7.5.2 A copper alloy part containing more than 15 percent zinc shall be tested for stress corrosion cracking.

7.5.3 A copper alloy part containing more than 15 percent zinc shall show no evidence of cracking when examined using a 25X magnification after being subjected to the stress corrosion/moist ammonia (NH₄) test as specified in 9.5.

7.6 Stress corrosion/mercurous nitrate (HgNO₃)

7.6.1 A copper alloy part of an equipment wiring terminal shall be resistant to stress corrosion cracking.

Note: The mercurous nitrate test is considered an alternative to the moist ammonia test.

7.6.2 A brass part containing less than 80 percent copper shall not crack when subjected to the stress corrosion/mercurous nitrate (HgNO₃) test in 9.6.

8 Sampling Requirements

8.1 General

8.1.1 See Table 6 for the minimum number of specimens for test.

8.1.2 Separate specimen sets shall be used for current-cycling, mechanical sequence, static-heating sequence, dielectric-withstand tests and the other tests as applicable. See Table 1 and Table 2.

8.1.3 The basic specimen set for the current-cycling tests, mechanical sequence, and static-heating sequence shall consist of four equipment wiring terminals for each combination of equipment wiring terminal and test conductor or conductors to be tested.

8.1.4 For a line of equipment wiring terminals of similar design but of different sizes, the following sizes shall be tested:

- a) the largest and the smallest sizes if the line consists of four sizes or less;
- b) the largest, smallest, and one representative intermediate size if the line consist of five sizes; and
- c) the largest, smallest, and two representative intermediate sizes if the line consists of more than five sizes.

8.1.5 A line of equipment wiring terminals of similar design is determined by the following features:

- a) shape of equipment wiring terminal, shape of conductor opening, and shape and number of clamping screws;
- b) material and surface treatment of the equipment wiring terminal body, tang, clamping screw, and pressure bar;
- c) torque corresponding to the wire size of each equipment wiring terminal;
- d) crimping die design and number of crimps for equipment wiring terminals using crimping tools; and
- e) for a tangless type equipment wiring terminal, the material and plating of the associated tang to be used with the equipment wiring terminal.

8.1.6 Specimens shall be tested using both solid and stranded conductor for 30 – 10 AWG (0.05 – 5.3 mm²) conductor sizes, and using stranded conductor for 8 AWG (8.4 mm²) and larger unless the conductor is marked in accordance with 10.13, in which case the conductor used shall be of the type or types marked on the equipment wiring terminal.

8.1.7 If the conductor range of an equipment wiring terminal includes sizes 14 – 10 AWG (2.1 – 5.3 mm²), and these sizes are not included in the test sample selection, additional sample sets shall be tested using the maximum size solid conductor in the range of 14 – 10 AWG (2.1 – 5.3 mm²).

8.1.8 Testing using AWG/kcmil conductors is representative of Class 1 and 2 metric conductors (rigid solid and rigid stranded) within the cross-sectional area envelope of the rated AWG/kcmil range. Class 5 and 6 metric conductors (flexible stranded) shall additionally comply with the requirements in 7.1.9.

8.1.9 An equipment wiring terminal that is designed to employ clamping screws made for either aluminum, brass, or steel shall be tested with clamping screws made of the material specified in Table 7.

8.2 Current-cycling

8.2.1 For an equipment wiring terminal without an assigned ampere rating, specimens shall be tested using the maximum size conductor or conductors. For an equipment wiring terminal intended for a single conductor and also for paralleling conductors, current-cycling tests shall be conducted on specimens using the maximum single and maximum parallel conductor sizes. For an equipment wiring terminal that is intended for a range of conductor sizes and for copper conductor in addition to aluminum conductor, current-cycling tests with copper conductor need not be performed if the size that is selected results in a test current that is less than or equal to the test current used in the tests with aluminum conductor. Also see 7.1.4.

Note: The current used in the tests with aluminum conductor may be raised above the required value with the concurrence of those concerned.

8.2.2 For an equipment wiring terminal with an assigned ampere rating, specimens shall be tested using the size or sizes of the conductor corresponding to the assigned maximum ampere rating and equipment wiring terminal temperature rating as indicated in Table 4. If the assigned maximum ampere rating of an equipment wiring terminal falls between the two values of assigned ampere rating specified in these tables, the test current used shall be that which corresponds to the higher assigned rating. For an equipment wiring terminal intended for paralleling conductors, the conductor sizes shall be selected in accordance with Table 4, and the current shall be selected in accordance with Table 8. For an equipment wiring terminal that is intended for a range of conductor sizes and for copper conductors in addition to aluminum conductors, current-cycling tests with copper conductors are not required to be conducted if the size that is selected results in a test current that is less than or equal to the test current used in the tests with aluminum conductors.

Note: The current used in the tests with aluminum conductors may be raised above the required value with the concurrence of those concerned.

8.2.3 For an equipment wiring terminal with an assigned ampere rating and intended for a single conductor and also for paralleling conductors, the current-cycling test shall be conducted on specimens using the conductor combination or conductor size as selected for the static-heating test. For an equipment wiring terminal that is intended for a range of conductor sizes and for copper conductors in addition to aluminum conductors, heat-cycling tests with copper conductors need not be conducted if the size that is selected results in a test current that is less than or equal to the test current used in the tests with aluminum conductors.

Note: The current used in the tests with aluminum conductors may be raised above the required value with the concurrence of those concerned.

8.2.4 With reference to 7.1.6 and Table 3, if the equipment wiring terminal is intended for the intermixing of conductors of different materials, the current cycling tests shall be conducted using the following conductor material:

- a) maximum size copper with maximum size aluminum;
- b) maximum size copper with minimum size aluminum;
- c) minimum size copper with minimum size aluminum; and
- d) maximum size copper in combination with a minimum size aluminum conductor or conductors where the sum of test currents of the minimum size conductors is approximately equal to the current of the maximum size conductor.

The test currents are based on the lesser current dictated by the two different conductor materials.

8.3 Static-heating sequence

8.3.1 An equipment wiring terminal without an assigned ampere rating and intended for use with a range of conductor sizes shall be tested with the maximum size conductor. If more than one conductor is secured by a single clamping means, additional specimens shall be subjected to this test or the mechanical sequence test, as necessary.

8.3.2 For an ampere-rated equipment wiring terminal not intended for paralleling conductors, the static-heating sequence shall not be conducted with the larger size(s) of conductor that exceed the size conductor that corresponds to the ampere rating of the conductor as determined from Table 4; only the mechanical sequence tests shall be conducted. An equipment wiring terminal specimen set with the size conductor that corresponds to the ampere rating shall be subjected to the full static-heating sequence.

Note: See Annex B for example.

8.3.3 For an ampere-rated equipment wiring terminal intended for paralleling conductors, specimens shall be tested with the parallel conductor combinations that equal the assigned ampere rating as determined from Table 4. The ampere rating assigned to the equipment wiring terminal shall be divided by the number of conductors. For ampere ratings that fall between two consecutive values, the next larger conductor size shall be used. The values of test current in the static-heating test for the parallel-conductor range shall be selected from Table 5. If the number of conductors is less than the number of conductor openings, the conductors shall be positioned in the equipment wiring terminal so that the test current is concentrated in the smallest cross-sectional area of the equipment wiring terminal in the current path. If the equipment wiring terminal also has single conductor ranges, the conductor sizes and values of test current in the static-heating tests for the single conductor ranges shall be selected from Table 4 using the conductor size that corresponds to the ampere rating of the equipment wiring terminal.

Note: See Annex B for example.

8.3.4 For the static-heating sequence where intermixing of conductor types is involved, the same selection of samples as indicated in 8.2.4 shall be tested.

8.4 Mechanical sequence

8.4.1 For the mechanical sequence, equipment wiring terminals intended for use with a range of conductor sizes shall be tested with the maximum and minimum size conductor. The mechanical sequence on any particular conductor size need not be repeated if it has been conducted as part of the static-heating sequence. If more than one conductor is secured by a single clamping means, additional specimens shall be selected for this test, as necessary.

8.5 Stress corrosion/moist ammonia (NH₄)

8.5.1 The number of specimens as identified in Table 6 shall be subjected to the stress corrosion/moist ammonia (NH₄) test described in 9.5.

8.6 Stress corrosion/mercurous nitrate (HgNO₃)

8.6.1 The number of specimens as identified in Table 6 shall be subjected to the stress corrosion/mercurous nitrate (HgNO₃) test described in 9.6.

8.6.2 The test shall be conducted on a specimen previously unused and not attached to a conductor or otherwise subjected to external stress.

9 Test Methods

9.1 General

9.1.1 Temperature measurement

9.1.1.1 Temperatures shall be measured by thermocouples consisting of conductors not larger than 24 AWG (0.21 mm²) and not smaller than 30 AWG (0.05 mm²).

9.1.2 Ambient temperature measurement

9.1.2.1 Test assemblies shall be located in a substantially vibration and draft-free location where the average ambient air temperature shall be maintained in the range of 15°C – 35°C. The ambient temperature shall be kept within ± 4°C at all times during the test.

9.1.2.2 Thermocouples to measure the ambient temperature for an equipment wiring terminal specimen under test shall be installed on 50.8 mm (2 in) square x 6.4 mm (1/4 in) thick sections of unplated copper bus. All buses shall be mounted in a vertical plane at the same elevation as the wire equipment wiring terminals being tested. All measurements shall be made to the centerline of the nearest equipment wiring terminal or control conductor. If all thermocouples employed are the same length, they shall be connected in parallel to provide an average ambient temperature.

9.1.2.3 For vertically mounted equipment wiring terminals, one bus shall be located 610 mm (2 feet) in front, one bus 610 mm (2 feet) in back of the specimens and control conductor. For test assemblies employing an insulating backboard as mentioned in 9.1.10.10, no bus section shall be mounted behind the test assembly.

9.1.2.4 For horizontally mounted equipment wiring terminals in an assembly of one or more specimens of equipment wiring terminals, bus sections shall be located 610 mm (2 feet) in front, 610 mm (2 feet) in back, and 610 mm (2 feet) on each side of the test assembly. An alternate method of locating the thermocouple for a horizontal test assembly is to place one bus at the center of a loop formed by the specimens and control conductor.

9.1.3 Control conductor temperature measurement

9.1.3.1 A thermocouple shall be located on each control conductor. For control conductors used when testing an equipment wiring terminal intended for paralleling conductors, the thermocouples shall be the same length and connected in parallel to determine the average control conductor temperature.

9.1.3.2 A thermocouple on a control conductor used in the current-cycling test shall be located at the midpoint of the conductor and under the conductor insulation. The thermocouple shall be secured by soldering, by use of an adhesive, or by other equivalent means. The conductor insulation shall be replaced over the thermocouple location. The surface of the conductor metal shall not be penetrated. Drilling and peening shall not be used.

9.1.3.3 For temperature measurements on a copper control conductor, the following technique shall be employed:

- a) A small flap shall be cut into the conductor insulation and rolled back to expose the conductor.
- b) The thermocouple bead shall be positioned in the valley between conductor strands or on the surface of a solid conductor.
- c) The flap of insulation shall be repositioned and secured by a tightly wrapped, double layer of black thermoplastic tape extending not more than 12.7 mm (1/2 in) on each side of the flap, or by another similar means of holding the test conductor insulation in place.

9.1.3.4 For temperature measurements on an aluminum control conductor, if a thermally conductive adhesive which maintains direct contact with the strand of the control conductor is used, the technique specified in 9.1.3.3 shall be used. When a thermally conductive adhesive is not used, the following technique shall be used:

- a) A 25.4 mm (1 in) minimum length of insulation over the full circumference of the conductor shall be removed.
- b) For a solid conductor, the thermocouple shall be secured to the surface of the conductor.
- c) One conductor strand shall be pried out of the stranding just enough to insert the end of a soft copper ribbon measuring 6.4 mm (1/4 in) wide x 0.13 mm (0.005 in) thick to a length that overlaps approximately 3.2 mm (1/8 in) as illustrated in Figure 1. The conductor strand shall then be lightly tapped back down on the copper ribbon.
- d) The copper ribbon shall be wrapped partially around the conductor strands back to the one strand that has been pried out.
- e) The thermocouple shall be located on the copper ribbon in the valley formed by the pried-out strand and the adjacent strand and shall be soldered in place. The copper ribbon shall be wrapped completely around the bundle of strands and shall be cut off so that a 3.2 mm (1/8 in) overlap results. The ribbon shall be secured in place by reheating the solder behind the ribbon where the thermocouple is located.
- f) The section of insulation removed as described in a) shall be attached with the slit side directly opposite the thermocouple junction. Thin-walled heat shrinkable 125°C tubing or a tightly wrapped, double layer of black thermoplastic tape extending not more than 12.7 mm (1/2 in) on each end of the section of insulation shall be used to hold it in place.

9.1.4 Specimen temperature measurement

9.1.4.1 A thermocouple on an equipment wiring terminal shall be positioned to sense the highest temperatures generated by the equipment wiring terminal. In general, the thermocouple sensing bead shall be located on one of the conductor entry sides of the equipment wiring terminal and closest to the conductor/equipment wiring terminal contact surface. A thermocouple shall be installed so as to obtain thermal and mechanical bonding with the surface of an equipment wiring terminal and without causing an appreciable change in the temperature of the equipment wiring terminal, for example, by peening thermocouples into small holes drilled in the equipment wiring terminal or by the use of small quantities of an adhesive.

9.1.4.2 A test specimen shall be considered stable during the static-heating test when three temperature readings taken at not less than 10 min intervals show no more than a 2°C variation between the three consecutive readings.

9.1.5 Test and control conductors

9.1.5.1 All test specimen conductors and control conductors shall comply with the requirements in Table 9, Table 10, and Table 11. All test specimen conductors and control conductors shall be new (previously unused) or, with the concurrence of those concerned, shall be previously used conductors that have not attained a temperature of over 120°C. For previously used conductors, used conductor ends shall be cut off and the resulting new ends of the conductor re-stripped in accordance with 9.1.6.

9.1.5.2 Equipment wiring terminals additionally rated for 2 AWG (33.6 mm²) and larger compact-stranded copper conductors shall be tested with compact-stranded Class B copper conductors. See also 6.1.2 and 10.12.

9.1.5.3 An equipment wiring terminal for flexible copper wire other than Class B or Class C stranding shall be subjected to all test sequences using the other stranding.

9.1.5.4 With the concurrence of those concerned, the test specimens and conductors used in the current-cycling test for the evaluation of a 75°C rated equipment wiring terminal may be used to evaluate the equipment wiring terminal for a 90°C rating at the required new test current and for an additional 500 cycles.

9.1.5.5 The insulation for conductors shall be black or, with the concurrence of those concerned, insulation color other than black shall be allowed.

9.1.5.6 The conductor shall be examined to verify that the insulation has not penetrated beyond the first strand layer during the manufacturing process.

Note: A separator may be located between the conductor and the insulation of a stranded conductor to attain required separation.

9.1.5.7 The length measured from the conductor entry face of the test equipment wiring terminal to the equalizer for the current-cycling test or to the face of the equipment wiring terminal at the other end of the test conductor for the mechanical or static-heating test shall be as specified in Table 12.

9.1.5.8 The length of control conductors used in the current-cycling tests shall be a minimum of twice the length of the test conductors used with the equipment wiring terminal specimens.

9.1.5.9 The length of control conductors used in the current-cycling tests shall be a minimum of twice the length of the test conductors used with the equipment wiring terminal specimens.

9.1.6 Conductor stripping

9.1.6.1 Conductors shall be stripped immediately prior to installation for a distance that is proper for insertion into the equipment wiring terminal and shall be assembled in the equipment wiring terminal in the intended manner. The conductor shall not be brushed or abraded prior to installation into the equipment wiring terminal.

Note 1: Care should be taken in stripping conductors to avoid cutting, nicking, scraping, or other damage to the conductors. Care should be taken in removing all foreign materials such as insulation, separators, and the like from the stripped ends.

Note 2: For an insulation piercing type equipment wiring terminal, the removal of the outer sheath of a cable, if necessary, is not considered to be a previous stripping.

9.1.6.2 For an equipment wiring terminal marked with a nominal strip length according to footnote a of Table 13, all tests, except for the dielectric-withstand test, shall be performed with conductors stripped to the nominal value minus the tolerance specified in Table 14.

9.1.6.3 For an equipment wiring terminal marked with a minimum conductor strip length, all tests shall be conducted with conductors stripped to the minimum length.

9.1.6.3.1 If the strip length is not provided in accordance with footnotes b and c of Table 13, the insulation of the test conductor shall be stripped to allow the conductor to make contact with the full available length of the equipment wiring terminal collar or barrel that contains the securing means. The conductor shall be positioned so that 6.4 – 12.7 mm (1/4 – 1/2 in) of bare conductor is exposed between the conductor-entry face of the equipment wiring terminal and the beginning of the insulation. If the conductor projects through the equipment wiring terminal without interference, the conductor shall be installed to project a maximum of 6.4 mm (1/4 in).

9.1.7 Equalizer

9.1.7.1 For the current-cycling test, each stranded control conductor and each stranded conductor that has been terminated or is intended to be terminated in an equipment wiring terminal shall have the free end welded or brazed to an equalizer to make a thorough electrical connection for each strand. Tool-applied compression connectors without welding may be used.

Note 1: An equalizer is not required but can be used for a solid test conductor.

Note 2: Equalizers need not be used on specimens intended for any other tests, as it is necessary to insert the open end of the conductor through a bushing for the secureness test.

9.1.7.2 An equalizer shall be constructed using:

- a) a short length of copper or aluminum bus having one or more holes slightly larger than the conductor;
- b) a tool-applied compression connector; or
- c) a pressure screw-type wire connector having an open end opposite the conductor insertion end.

9.1.7.3 The end of the conductor that projects through the equalizer shall be welded into a homogeneous mass with the bus [see 9.1.7.2(a)] or the connector [see 9.1.7.2(c)]. For a equipment wiring terminal intended for paralleling conductors, the hole spacing pattern in the equalizer shall be identical to the hole spacing pattern in the equipment wiring terminal. A wire connector used as an equalizer shall not be larger than that needed for the conductor size involved, and an equalizer bus shall not be larger than the applicable bus size indicated in Table 15. For test currents over those in Table 15, the size of the equalizer shall be based on 1.55 A/mm^2 ($1\,000 \text{ A/in}^2$) of cross-section for a copper bus equalizer and 1.16 A/mm^2 (750 A/in^2) of cross-section for an aluminum bus equalizer.

9.1.8 Preparation of specimens

9.1.8.1 Representative specimens of the equipment wiring terminal shall be assembled to conductors of the proper type, length, and size and in the manner used in service. For the current-cycling test, control-conductor assemblies shall also be prepared. These control-conductor assemblies shall be wired in series with the specimens used for the current-cycling test and shall carry the same test current. For an equipment wiring terminal intended for paralleling conductors, the number of control conductors shall be equal to the number of conductors being tested.

9.1.8.2 If an equipment wiring terminal is intended for assembly by means of a specific tool, this tool shall be used in the intended manner.

9.1.8.3 If an equipment wiring terminal is intended to be assembled to a conductor by means of more than one type of specific tool, the equipment wiring terminal shall meet the requirements when any of the specific tools are employed in the assembly operation.

9.1.8.4 With reference to 9.1.8.3, in selecting tools for assembly of an equipment wiring terminal to a conductor, the following features shall be considered:

- a) profile, width, and depth of the equipment wiring terminal;
- b) material of equipment wiring terminal body;
- c) crimping die geometry;
- d) the number of crimps; and
- e) similarity of crimp forces.

9.1.8.5 If specific instructions for assembling the equipment wiring terminal to the conductor are furnished with the equipment wiring terminal, such instructions shall be followed in the preparation of the specimens, except that the conductor shall not be brushed or abraded and an antioxidant shall be used only if the equipment wiring terminal is prefilled with the antioxidant. See 10.15.

9.1.8.6 A tangless type equipment wiring terminal (e.g., collar or meter-socket construction) shall be mounted for test purposes on a tang representative of the intended use; see 9.1.8.8. The length of the tang shall not exceed twice the length of the equipment wiring terminal body. For the static-heating sequence and mechanical sequence, individual tangs with a mounting hole in the end opposite the equipment wiring terminal shall be used. For the current-cycling test, one tang with equipment wiring terminals mounted as illustrated in Figure 2 shall be used. If the specified mounting means includes auxiliary antirotation means, such means shall not increase the thermal mass or heat-radiating capabilities of the assembly.

9.1.8.7 With reference to 9.1.8.6, a equipment wiring terminal integral with a fuse clip, meter-socket jaw, or similar feature, intended for connection to a bus having a low conductivity shall have the tang sized to reduce the risk of over-heating of the tang. The test tang shall not be so large that it operates cooler than the bodies of the equipment wiring terminal as determined by thermocouples placed on the tangs and equipment wiring terminal bodies.

9.1.8.8 For a tangless type equipment wiring terminal (see Figure 2), the following information shall be provided:

- a) material of tang;
- b) plating on tang;
- c) minimum cross-section of tang;
- d) material of mounting screw;
- e) use of a washer, type and size; and
- f) torque to be used to secure the equipment wiring terminal to the tang.

9.1.9 Tightening torque

9.1.9.1 The connection between the conductor and the equipment wiring terminal shall be made before the start of the first test on any specimen set. No additional tightening shall be performed during the testing program.

9.1.9.2 An equipment wiring terminal shall be mounted to a test bus according to the manufacturer's minimum specifications. During application of the tightening torque the equipment wiring terminal assembly shall be free to turn about its mounting means except as restricted by the design of the equipment wiring terminal or the specified mounting means. Subsequent turning of the equipment wiring terminal about its mounting means shall only occur due to test procedures such as those for the secureness test. The mounting means shall not be retightened during the testing program.

9.1.9.3 The specified torque shall be applied by tightening the connection between the conductor and the equipment wiring terminal until the specified value of torque is attained and maintaining this value, with a constant torque reading, for 5 s.

9.1.9.4 Except as allowed in 9.1.9.5, the tightening torque values specified in Table 16, Table 17, or Table 18 shall apply to all equipment wiring terminals employing conductor clamping nuts or bolts of the types described in the tables. The values in Table 16 are based on the size of the installed test conductor, while the torque values specified in Table 17 and Table 18 are independent of the installed test conductor. Table 17 is limited for use with equipment wiring terminals intended for 8 AWG (8.4 mm²) or smaller conductors. If more than one conductor is secured under the same clamping nut or bolt, the torque value in Table 16 shall be applied based on the largest conductor installed. Specimens prepared for the current-cycling test shall be tightened using the values of torque shown in column A. All other tests shall have the specimens prepared using the values in column B.

9.1.9.5 With reference to 9.1.9.4, when a tightening torque value is assigned, the current-cycling test specimens shall be prepared using 90 percent of the assigned torque value. All other tests shall have the specimens prepared using the assigned value of torque. See 10.22 for marking requirements.

9.1.9.6 Equipment wiring terminals having clamping screws with multiple tightening means (for example, a combination slotted, hexagonal head screw) shall be tested using the multiple values of torque as specified in Table 16, Table 17, and Table 18.

9.1.10 Test assembly

9.1.10.1 Specimens and the control conductor shall be connected in series and to a current source. Tang-type equipment wiring terminals shall be bolted back-to-back, and equalizers shall be bolted together or to lengths of bus using the hardware specified in 9.1.10.2.

9.1.10.2 The following hardware shall be used to make the connections mentioned in 9.1.10.1; once the initial assembly is completed, there shall be no subsequent retightening:

- a) A bolt shall be plated steel, SAE Grade 2, UNC thread having a maximum standard diameter compatible with the hole or holes in the equipment wiring terminal tang and a minimum standard length allowing at least a 2-thread projection through the nut, and the projection shall not exceed 6.4 mm (1/4 in) after assembly.
- b) A single flat washer shall be used on each side of the tang-to-tang or tang-to-bus connection. These washers shall be plated steel having an SAE configuration compatible with the diameter of the bolt.
- c) A nut shall be plated steel, and shall have a Class 2B, UNC thread and a hexagonal configuration.
- d) Clean, dry, nonlubricated screws and bolts and nuts shall be used.
- e) The assembled hardware shall be torqued to the values in Table 19.

9.1.10.3 When the installation instructions (see 10.21) specify that a dished washer shall be used, the design of the dished washer shall be such that the force needed to flatten the washer is as specified for the corresponding bolt size in Table 20. The hardware shall be as follows:

- a) One plated or stainless steel dished washer per securing bolt shall be used.
- b) A flat washer as mentioned in 9.1.10.2(b) shall be used on the side of the tang-to-tang or tang-to-bus connection opposite the dished washer.
- c) Tests on an equipment wiring terminal shall be conducted using other hardware, part securement torque values, and dished or other washers having different characteristics, if the installation instructions specify all necessary hardware and torque. See 10.21.

9.1.10.4 The lengths of the busbars mentioned in 9.1.10.1 shall be the minimum necessary to provide sufficient contact area for the equalizers while maintaining the center-to-center specimen spacing specified in 9.1.10.5. The cross-section dimensions of the bar shall be sufficient to prohibit a test-current density in excess of 1.55 A /mm² (1 000 A /in²) for copper or 1.24 A /mm² (800 A /in²) for aluminum bus. See Table 15.

9.1.10.5 Individual equipment wiring terminal/conductor specimens shall be separated by at least 457 mm (18 in) when measured center-to-center.

9.1.10.6 With reference to 9.1.10.5, the spacing may be reduced with the concurrence of those concerned.

9.1.10.7 With reference to 9.1.10.5, the spacing may be reduced to a minimum of 152 mm (6 in) if a thermal barrier is used between assemblies. The thermal barrier shall extend at least 152 mm (6 in) in a vertical direction and 25.4 mm (1 in) in a horizontal direction beyond the extremities of the equipment wiring terminal.

9.1.10.8 Test assemblies and the control conductor shall be suspended vertically or horizontally in free air by the use of loose-fitting, nonmetallic tie straps around the conductors or by suspension from the equalizers supported in turn by nonmetallic blocks. The method used shall reduce the disturbance of the test connections during handling of the specimens and reduce the transmission of tensile loads to the test equipment wiring terminals through test or supply conductors. See Figure 3 for an example of a vertical arrangement.

9.1.10.9 The temperature measurement location for the control conductor and equipment wiring terminal samples shall be located a minimum of 610 mm (24 in) from the building floor, ceiling, and walls.

9.1.10.10 With reference to 9.1.10.9, the spacing need not be maintained if a solid insulating backboard separates the test samples from the building floor, ceiling, or walls. Samples shall be spaced at least 102 mm (4 in) from the insulating backboard.

9.2 Current-cycling

9.2.1 For an equipment wiring terminal intended for paralleling conductors, the on-time shall be the time it takes for the equipment wiring terminal to reach stable temperatures. The off-time shall be the time it takes to reach room temperature. These times shall be determined in the first 25 cycles of operation. A test specimen has attained a stable temperature during the current on-time when three readings show no more than a 2°C variation between any two of the readings. The time to temperature stabilization for the current-off time is the first of three readings indicating stable temperature.

9.2.2 Temperatures shall be measured and recorded for at least 1 cycle of each working day.

9.2.3 Temperatures shall be measured no sooner than the last 5 min of the normal current-on time. If the size of the test specimen set or the speed of the data acquisition system is such that not all measurements are completed within 5 min, the current-on time shall be extended as necessary to complete such measurements.

9.2.4 The current-off times may be reduced after the first 25 cycles of testing to 5 min more than the maximum time it takes any equipment wiring terminal to reach a stable temperature during the current-off period. Forced-air cooling may be employed to reduce the current-off time with the concurrence of those concerned. A test specimen has attained a stable temperature during the current-cycling test when three readings at 10 min intervals show no more than a 2°C variation between any two of the readings. The time to temperature stabilization is the current-off time at which the first of three readings indicating stable temperature was recorded.

9.2.5 For an equipment wiring terminal intended for paralleling conductors, the initial currents through the conductors shall be balanced so that the highest current in a conductor is not more than 125 percent of the current in any parallel conductor. Current balance need not be attained if agreeable to those concerned.

9.3 Static-heating sequence

9.3.1 Static-heating test

9.3.1.1 Specimens shall be selected and prepared as described in Clause 8 and 9.1.8, except that equalizers shall not be used.

9.3.1.2 The test assembly and securing hardware shall be as described in 9.1.10.

9.3.2 Secureness test

9.3.2.1 An equipment wiring terminal shall be fastened to a length of conductor not less than 76 mm (3 in) longer than the height specified in Table 21, and shall be rigidly secured in a vertical position simulating actual service conditions. The free end of the conductor shall be passed through a bushing of the size specified in Table 21. The bushing shall be attached to an arm driven by a motor at a rate of approximately 9 rpm and in such a manner that the center of the bushing describes a circle in a horizontal plane. See Figure 4. The circle shall have a diameter of 76 mm (3 in), and its center shall be vertically below the center of the conductor opening in the equipment wiring terminal. The distance between the upper side of the bushing and the mouth of the equipment wiring terminal shall be within 12.7 mm (1/2 in) of height specified in Table 21. The bushing shall be lubricated so there is no binding, twisting, or rotation of the insulated conductor. A mass as specified in Table 21 shall be suspended from the free end of the conductor.

9.3.2.2 If an equipment wiring terminal is intended to secure more than one conductor at a time by a single clamping means, only one conductor in each combination shall be tested for secureness. If the conductors in the combination are of different sizes, separate specimens shall be used for testing each size of conductor.

9.3.2.3 For an equipment wiring terminal intended for paralleling conductors, the test shall be performed on four specimens of entry hole if all conductor entry holes are identical in construction. If entry holes are not identical, then the test shall be repeated using four different entry holes to represent the different constructions.

9.3.3 Repeated static-heating test

9.3.3.1 The sample sets previously subjected to the static-heating test and the secureness test shall be subjected to another static-heating test as described in 9.3.1.

9.3.3.2 With reference to 9.3.3.1, an equipment wiring terminal designed for paralleling conductors need not be subjected to this test.

9.3.4 Pullout test

9.3.4.1 The same equipment wiring terminals and entry holes subjected to the secureness test shall be subjected to a direct pull of the applicable value specified in Table 22. For an equipment wiring terminal intended to secure more than one conductor at a time by a single clamping means, only those conductors that have been subjected to the secureness test shall be subjected to the pullout test.

9.3.4.2 The pull shall be exerted by means of a tension-testing machine, dead weights, or other equivalent means so that there is no sudden application of force or jerking during the test.

9.4 Mechanical sequence

9.4.1 Secureness test

9.4.1.1 The test procedure described in 9.3.2 shall be conducted.

9.4.2 Pullout test

9.4.2.1 The test procedure described in 9.3.4 shall be conducted.

9.5 Stress corrosion/moist ammonia (NH₄)

9.5.1 Each test specimen shall be subjected to the physical stresses normally imposed on or within a part as the result of assembly. Such stresses shall be applied to the specimens prior to and maintained during the test. Specimens shall be assembled to a 152 mm (6 in) length of the maximum rated size conductor and torqued to the value in 9.1.9.4 or 9.1.9.5.

9.5.2 The specimens shall be degreased and then continuously exposed in a set position for 10 d to a moist ammonia-air mixture maintained in a glass chamber approximately 305 x 305 x 305 mm (12 x 12 x 12 in) having a glass cover.

9.5.3 Approximately 600 ml of aqueous ammonia having a specific gravity of 0.94 shall be maintained at the bottom of the glass chamber below the specimens. The specimens shall be positioned 38 mm (1-1/2 in) above the aqueous ammonia solution and supported by an inert tray. The moist ammonia-air mixture in the chamber shall be maintained at atmospheric pressure and a temperature of 34 ±2°C.

9.6 Stress corrosion/mercurous nitrate (HgNO_3)

9.6.1 Specimens shall be immersed in an aqueous solution of 100 g of mercurous nitrate and 13 ml of nitric acid (specific gravity of 1.42) per liter for 15 min. Evidence of cracking shall be determined with normal or corrected vision without magnification.

10 Marking, Labeling, and Packaging

10.1 Required marking locations shall be in accordance with 10.3 – 10.31. Refer to Annex D as a guide for marking locations.

10.2 The requirements in 10.3 – 10.31 are applicable to equipment wiring terminals which are not an integral part of the equipment. For marking of equipment wiring terminals which are an integral part of the equipment, refer to the appropriate equipment standard.

10.3 A equipment wiring terminal shall be legibly marked with:

- a) the manufacturer's name, trademark, or other descriptive marking by which the organization responsible for the product is identified;
- b) a distinctive catalog number or the equivalent; and
- c) the conductor size or ranges of sizes.

10.4 In lieu of the markings in 10.3 (b) or (c), or both, an equipment wiring terminal that is for use only with conductors smaller than 8 AWG (8.4 mm^2) shall be marked with a single identifying symbol. This symbol may be an individual catalog number, a type designation, a size designation, such as 12, or an equivalently significant symbol. Each unit container containing equipment wiring terminals so identified or an information sheet packed in the unit container shall be marked with the information specified in 10.3 (a), (b), and (c). A type designation is intended primarily to identify a particular design, which may include various features covered by different catalog numbers.

10.5 With reference to 10.3(c), the conductor-size marking on an equipment wiring terminal intended for assembly to a conductor(s) by means of a specific tool may be a symbol or color, provided that its significance, in terms of a conductor size or sizes, is clearly marked on the tool (die).

10.6 An equipment wiring terminal intended for copper conductor only shall be legibly marked with "CU" on:

- a) the equipment wiring terminal;
- b) its unit container; or
- c) an information sheet packed in the unit container.

10.7 An equipment wiring terminal rated for use with aluminum conductor only shall be legibly marked with the letters "AL". In lieu of the marking on the equipment wiring terminal, for equipment wiring terminals used with 6 AWG (13.3 mm^2) or smaller conductors, the letters "AL" may be marked on the unit container or on an information sheet packed in the unit container.

10.8 An equipment wiring terminal intended for use with aluminum and copper conductor shall be legibly marked "AL-CU" or "CU-AL". An equipment wiring terminal intended for use with aluminum or copper-clad aluminum and copper wire shall be plainly marked "AL-CU" or "CU-AL." An equipment wiring terminal intended for use with copper-clad aluminum and copper wire shall be plainly marked "CC-CU" or "CU-CC." In lieu of the marking on the equipment wiring terminal, for equipment wiring terminals used with 6 AWG (13.3 mm²) or smaller conductors, the letters "AL-CU", "CU-AL", "CC-CU" or "CU-CC" may be printed on the unit container or on an information sheet packed in the unit container.

10.9 If a equipment wiring terminal is intended for use with an aluminum conductor, copper-clad aluminum conductor, or both, of one size or range of sizes and with a copper conductor of a different size or range of sizes, the conductor-size marking shall clearly differentiate the size or range of sizes of the aluminum conductor, copper-clad aluminum conductor, or both; and also the size or range of sizes of the copper conductor, for which the equipment wiring terminal is rated.

10.10 In regards to 10.9, a single wire range may be marked when:

- a) the maximum wire size for both copper and aluminum is the same; and
- b) the minimum aluminum wire size for both copper and aluminum is the same or the minimum copper wire size is smaller than 12 AWG (3.31 mm²).

Note: It is understood that the minimum available aluminum conductor size is 12 AWG (3.31 mm²), even though a wire range may include smaller copper wire sizes. For example: a wire range of 1/0 – 14 AWG (53.5 – 2.08 mm²) is interpreted as 1/0 – 14 AWG (53.5 – 2.08 mm²) copper conductors and 1/0 – 12 AWG (53.5 – 3.31 mm²) aluminum conductors.

10.11 Unless any rearrangement or adjustment of an equipment wiring terminal that is necessary to adapt it to various sizes of conductor is obvious, it shall be clearly indicated by size markings or other instructions appearing on:

- a) the equipment wiring terminal;
- b) its unit container; or
- c) an information sheet packed in the unit container.

10.12 An equipment wiring terminal, a unit container, or an information sheet packed in the unit container for an equipment wiring terminal tested with conductors other than Class B or Class C stranding (see 9.1.5.2) shall also be marked with the conductor class or classes and the number of strands.

10.13 An equipment wiring terminal tested with a solid or stranded conductor other than as specified in 8.1.6 shall be marked "Solid" or "Stranded" or with both markings as applicable. See 10.14.

10.14 The "Solid" and "Stranded" markings in 10.13 may be:

- a) abbreviated "Sol" and "Str" respectively; or
- b) provided on the unit container or on an information sheet packed in the unit container, if there is insufficient space on the equipment wiring terminal for either the complete or the abbreviated marking.

10.15 A procedure that must be followed for proper assembly of an equipment wiring terminal to a conductor shall be provided as follows:

a) **USE OF A SPECIFIC TOOL REQUIRED** – If an equipment wiring terminal is intended to be assembled to a conductor(s) by a specific tool, the tool designation or the designation of a removable tool part, such as a pressing die, shall be marked on the equipment wiring terminal, or on or within the unit container in which the equipment wiring terminal is packed. The marking shall be by at least one of the following means:

- 1) catalog or type designation;
- 2) color coding;
- 3) die index number; or
- 4) other equivalent means.

b) **MULTIPLE CRIMPING OPERATIONS** – Information shall appear either:

- 1) on the unit container in which the equipment wiring terminal is packed;
- 2) on the tool or pressing die that must be used for its application;
- 3) on the carrying case provided for permanent storage of the tool and dies; or
- 4) on the equipment wiring terminal.

Location of the crimping points only, without additional instructions, may be marked on the equipment wiring terminal if the additional required information is located as indicated in item 1), 2), or 3).

c) **CONDUCTOR STRIP LENGTH** – Strip length marking as specified in Table 13 shall appear:

- 1) on the equipment wiring terminal;
- 2) on the unit container or on an information sheet contained therein;
- 3) on an insulating cover; or
- 4) on the tool or on the carrying case provided for its permanent storage if:
 - i) the equipment wiring terminal requires the use of a specific tool for its application; and
 - ii) the strip length applies to all equipment wiring terminals with which the tool is used.

d) **PRELIMINARY PREPARATION OF CONDUCTOR REQUIRED** – Instructions for preparation of the conductors, such as use of compound or twisting conductors together before assembly, shall appear on the unit container or an information sheet packed in the unit container.

10.16 Copper-bodied equipment wiring terminals intended for copper conductors only are rated 90°C and are not required to be marked with an equipment wiring terminal temperature rating.

10.17 An aluminum-bodied equipment wiring terminal intended for copper conductors only (see 7.1.11) shall be marked with an equipment wiring terminal temperature rating in accordance with 10.18 (e.g., CU75, CU7, CU90, or CU9).

10.18 An equipment wiring terminal rated for AL or AL-CU shall be marked with the equipment wiring terminal temperature rating, 75°C or 90°C, as tested in the current-cycling test. In lieu of the marking on the equipment wiring terminal, for equipment wiring terminals used with 6 AWG (13.3 mm²) or smaller conductors, the temperature rating shall be printed on the unit container or on an information sheet packed in the unit container.

10.19 With reference to 10.18, a 7 may be used to represent a 75°C marking and a 9 may be used to represent a 90°C marking. For an equipment wiring terminal marked for use with only aluminum, the single digit shall follow the letters; for example, "AL7." The 7 or 9 shall be incorporated in place of the dash in a marking such as "AL-CU" or "CU-AL"; for example, "AL7CU" or "CU7AL."

10.20 An equipment wiring terminal intended for intermixing between conductor types shall be additionally marked "(intermixed - dry locations)" immediately following the marking in 10.18 or 10.19; for example, AL7CU (intermixed - dry locations). See 6.1.6.

10.21 Installation instructions specifying the proper assembly procedures as mentioned in 9.1.8.5 and for the securing hardware mentioned in 9.1.10.3 and 9.1.10.3(c) shall be provided on the unit container in which the equipment wiring terminal is packaged or on an information sheet packed in the unit container.

10.22 If the equipment wiring terminal has an assigned tightening torque value, as described in 9.1.9.5, the assigned value shall be marked where readily visible on:

- a) the equipment wiring terminal;
- b) the unit container; or
- c) an information sheet packed in the unit container.

10.23 An equipment wiring terminal with an assigned ampere rating shall be marked with the assigned ampere rating; for example, "100 A" in addition to the other applicable markings. For an equipment wiring terminal intended for conductor sizes 6 AWG (13.3 mm²) or smaller, the marking may be on the unit container or on an information sheet packed in the unit container.

10.24 A unit container or an information sheet shall be marked with:

- a) the manufacturer's name; and
- b) a distinctive catalog number of the equipment wiring terminal or the equivalent if the marking is provided as specified in 10.27.

10.25 An equipment wiring terminal additionally rated for use with metric conductors shall have the metric wire range marked in close proximity to the rated AWG/kcmil wire range either on the equipment wiring terminal, unit container, or information sheet within the unit container.

10.26 An equipment wiring terminal rated for use with metric conductors shall be marked in close proximity to the metric wire range marking with the following, as applicable:

- a) the letter "r" for rigid solid and rigid stranded; or
- b) the letter "f" for flexible.

10.27 The information in a marking shall not be divided between a unit container and an information sheet. If any of the required markings are placed either on the unit container or on the information sheet packed in the unit container, rather than on the equipment wiring terminal, then all applicable markings as specified in the clauses in their entirety shall be so placed.

10.28 With reference to 10.27, a unit container of ten or fewer equipment wiring terminals may be marked with a reference to an identifying number on an information sheet as described in 10.30.

10.29 The information sheet mentioned in 10.27 shall be marked with the manufacturer's name, an identifying number as mentioned in 10.28, the catalog number of the equipment wiring terminal to which it pertains or equivalent, and all the necessary information required by 10.14(b), 10.15, 10.18, 10.22, and 10.23. The information sheet, one for each unit container, shall be packed in the packaging container.

10.30 Equipment wiring terminals additionally rated for 2 AWG (33.6 mm²) and larger compact copper shall be marked "For compact-stranded copper conductors" or the equivalent on the equipment wiring terminal, unit container, or an information sheet packed in the unit container.

10.31 A unit container shall be marked with the following, "These equipment wiring terminals may only be used with specific equipment for which it has been found acceptable."

Table 1 – Test sequences for all connectors

(Clauses 7.1.1, 7.1.7 and 8.1.2)

Sequence			
1	2 ^a	3 ^b	4 ^c
Current-cycling	Static-heating Secureness Static-heating (repeated) Pullout	Secureness Pullout	Stress Corrosion
^a This series of tests is referred to as static-heating sequence. ^b This series of tests is referred to as mechanical sequence. ^c The stress corrosion test, either moist ammonia or mercurous nitrate, need only be conducted for copper alloy parts not conforming to the copper requirements in 7.5 and 7.6. Note – Table 1 applies to equipment wiring terminals for non-parallel applications, in which case Table 2 would not be applicable. However, some equipment wiring terminals may have dual functionality, both parallel and non-parallel, in which case both Tables are applicable.			

Table 2 – Test sequences for all equipment wiring terminals intended for parallel conductors

(Clauses 7.1.1, 7.1.7 and 8.1.2)

Sequence			
1	2	3 ^a	4 ^b
Current-cycling	Static-heating	Secureness Pullout	Stress Corrosion

^a This series of tests is referred to as mechanical sequence.

^b The stress corrosion test, either moist ammonia or mercurous nitrate, need only be conducted for copper alloy parts not conforming to the copper requirements in 7.5 and 7.6.

Note – Table 2 applies to equipment wiring terminals for parallel applications, in which case Table 1 would not be applicable. However, some equipment wiring terminals may have dual functionality, both parallel and non-parallel, in which case both Tables are applicable.

Table 3 – Conductor materials to be used in test sequences

(Clauses 7.1.6 and 8.2.4)

Conductor for which connector is intended	Conductor used in test sequences
Copper ^a	Copper
Aluminum ^a	Aluminum
Copper to copper ^b	Copper
Copper-clad aluminum	Copper-clad aluminum
Aluminum to aluminum ^b	Aluminum
Copper-clad aluminum to Copper-clad aluminum ^b	Copper-clad aluminum
Copper to aluminum ^b , intermixed	Copper to aluminum
Copper to copper-clad aluminum ^b , intermixed	Copper to copper-clad aluminum

Note

1) If a equipment wiring terminal is rated for copper to copper, aluminum to aluminum, and copper to aluminum (intermixed), the mechanical sequence with copper to aluminum conductor may be omitted.

2) In all test sequences, aluminum conductor represents tests with copper-clad aluminum conductor.

^a Single conductor in an opening.

^b Two or more conductors in an opening.

Table 4 – Test current for connectors intended for a single conductor, A

(Clauses 7.2.1, 7.3.1, 8.2.2, 8.3.2, and 8.3.3)

Conductor size, AWG or kcmil (mm ²)	Copper				Aluminum				On (and off) times for current-cycling hours ^f
	As-sign-ed max-imum amp-ere rat-ing ^b	Static-heating ^{a,c,g}	Current-cycling connector temperature rating ^a		As-sign-ed max-imum amp-ere rat-ing ^b	Static-heating ^{a,c,g}	Current-cycling connector temperature rating ^a		
			75°C ^{d,g}	90°C ^{e,g}			75°C ^{d,g}	90°C ^{e,g}	
30 (0.05)	—	3	3.5	4	—	—	—	—	1
28 (0.08)	—	3.5	4	5	—	—	—	—	1
26 (0.13)	—	5.5	6	8	—	—	—	—	1
24 (0.20)	—	7	8	10	—	—	—	—	1
22 (0.32)	—	9	12	13	—	—	—	—	1
20 (0.52)	—	12	16	17	—	—	—	—	1
18 (0.82)	—	17	19	24	—	—	—	—	1

Table 4 – Test current for connectors intended for a single conductor, A Continued

Conductor size, AWG or kcmil (mm ²)	Copper								Aluminum								On (and off) times for current-cycling hours ^f
	As-sign- ed max- imum amp- ere rat- ing ^b	Static-heating ^{a,c,g}		Current-cycling connector temperature rating ^a				As-sign- ed max- imum amp- ere rat- ing ^b	Static-heating ^{a,c,g}		Current-cycling connector temperature rating ^a						
				75°C ^{d,g}	90°C ^{e,g}					75°C ^{d,g}	90°C ^{e,g}						
16 (1.31)	—	18	20	31	—	—	—	—	—	—	—	—	1				
14 (2.08)	15	[20] 30	[22] 33	[27] 40	—	—	—	—	—	—	—	—	1				
12 (3.31)	20	[25] 35	[28] 39	[40] 54	15	[20] 30	[22] 33	[29] 43	1								
10 (5.26)	30	[40] 50	[45] 56	[60] 75	25	[30] 40	[34] 45	[46] 60	1								
8 (8.37)	50	70	80	100	40	55	60	77	1								
6 (13.3)	65	95	105	131	50	75	85	102	1								
4 (21.2)	85	125	140	175	65	100	110	140	1								
3 (26.7)	100	145	165	205	75	115	125	160	1								
2 (33.6)	115	170	190	240	90	135	150	190	1								
1 (42.4)	130	195	220	275	100	155	175	215	1								
1/0 (53.5)	150	230	255	320	120	180	200	250	1								
2/0 (67.4)	175	265	300	370	135	210	230	295	1								
3/0 (85.0)	200	310	345	435	155	240	270	335	1								
4/0 (107)	230	360	405	505	180	280	315	390	1-1/2								
250 (127)	255	405	445	565	205	315	350	440	1-1/2								
300 (152)	285	445	500	625	230	350	390	490	1-1/2								
350 (177)	310	505	555	708	250	395	435	555	1-1/2								
400 (203)	335	545	605	765	270	425	470	595	1-1/2								
500 (253)	380	620	690	870	310	485	540	680	2								
600 (304)	420	690	775	968	340	540	600	760	2								
700 (355)	460	755	850	1055	375	595	675	835	2								
750 (380)	475	785	885	1100	385	620	700	870	2								
800 (405)	490	815	920	1140	395	645	725	905	2								
900 (456)	520	870	980	1220	425	700	785	980	2								
1000 (507)	545	935	1045	1310	445	750	840	1050	2								
1250 (633)	590	1065	1185	1490	485	855	950	1195	3								
1500 (760)	625	1175	1320	1645	520	950	1065	1330	3								
1750 (887)	650	1280	1435	1790	545	1050	1175	1470	3								
2000 (1010)	665	1385	1540	1940	560	1150	1280	1610	3								

^a See 7.2, 8.2, and 9.2.

^b Values are for 75°C, not more than three conductors in raceway or cable ampacities, National Electrical Code, ANSI/NFPA 70.

^c Values are for 75°C single conductor in free air ampacities, National Electrical Code, ANSI/NFPA 70.

^d Values are approximately 112 percent of the static-heating test currents.

^e Values for 8 AWG (8.4 mm²) and larger conductors are approximately 140 percent of the static-heating test current.

^f See 9.2.4.

^g Values in brackets apply to equipment wiring terminals with assigned ampere ratings.

Table 5 – Static test currents for connectors intended for paralleling conductors, A

(Clauses 7.3.1 and 8.3.3)

Conductor sizes, AWG or kcmil (mm ²)	Number and material of conductors					
	Two		Three		Four	
	Copper	Aluminum	Copper	Aluminum	Copper	Aluminum
1/0 (53.5)	300	240	450	360	480	384
2/0 (67.4)	350	270	525	405	560	432
3/0 (85.0)	400	310	600	465	640	496
4/0 (107)	460	360	690	540	736	576
250 (127)	527	410	790	615	1 053	820
300 (152)	579	455	868	683	1 158	910
350 (177)	657	514	985	770	1 314	1 028
400 (203)	709	553	1 063	829	1 418	1 106
500 (253)	806	631	1 209	946	1 612	1 262
600 (304)	1 035	810	1 554	1 215	2 070	1 620
700 (355)	1 133	893	1 699	1 339	2 266	1 786
750 (380)	1 178	930	1 767	1 395	2 356	1 860
800 (405)	1 223	968	1 834	1 452	2 446	1 936
900 (456)	1 305	1 050	1 958	1 575	2 610	2 100
1 000 (507)	1 403	1 125	2 104	1 688	2 806	2 250
1 250 (633)	1 598	1 383	2 397	1 924	3 196	2 566
1 500 (760)	1 763	1 425	2 644	2 138	3 526	2 850
1 750 (887)	1 920	1 575	2 880	2 363	3 840	3 150
2 000 (1 010)	2 078	1 725	3 117	2 588	4 156	3 450

NOTES –

1) The currents for conductor sizes 1/0 – 4/0 AWG (53.5 – 107 mm²) are based on the National Electrical Code (NEC), NFPA 70, Table 310-16, 75°C column, multiplied by the number of conductors and de-rated by 80 percent.

2) The currents for conductor sizes 250 kcmil (127 mm²) and larger are in accordance with the NEC, NFPA 70, Sections 392-11(b) (1) and 392-11(b) (2) for Table 310-17 (free air ampacities), 75°C column, multiplied by the number of conductors and de-rated as follows:

250 – 500 kcmil (127 – 253 mm²) – de-rated by 65 percent

600 kcmil (304 mm²) and larger – de-rated by 75 percent

3) Any number of conductors other than tabulated are to be de-rated in accordance with the NEC, NFPA 70, Table 310-16, Note 8.

Table 6 – Minimum number of specimens for test

(Clauses 8.1.1, 8.5.1, and 8.6.1)

Clause	Test	Number of specimens
9.2	Current-cycling	4 of each combination of connector and test conductor(s) to be tested
9.3	Static-heating sequence	4 of each combination of connector and test conductor(s) to be tested
9.4	Mechanical sequence	4 of each combination of connector and test conductor(s) to be tested
9.5 or 9.6	Stress corrosion	3

Table 7 – Material of clamping screws for tests

(Clause 8.1.9)

Screw material	Static-heating and mechanical sequences			Current-cycling		
	Steel	Copper alloy	Aluminum	Steel	Copper alloy	Aluminum
Steel, copper alloy, or aluminum	X	–	X	X	–	X ^a
Steel or aluminum	X	–	X	X	–	X ^a
Steel or copper alloy	X	X	–	X	X ^b	–
Aluminum or copper alloy	–	X	X	–	X ^b	X

Note – An X indicates that the test shall be conducted.

^a Tests need not be conducted on aluminum screws if the temperature for the aluminum screws in the static sequence is less than that for the alternate screw material.^b Tests need not be conducted if the temperature recorded for a copper alloy clamping screw in the static sequence is less than that determined for the alternate screw material.**Table 8 – Cycling test currents for 75°C and 90°C connectors intended for paralleling conductors, A**

(Clause 8.2.2)

Conductor size, AWG or kcmil (mm ²)	Number and material of conductors											
	Two				Three				Four			
	Copper		Aluminum		Copper		Aluminum		Copper		Aluminum	
	75°C	90°C	75°C	90°C	75°C	90°C	75°C	90°C	75°C	90°C	75°C	90°C
1/0 (53.5)	336	420	269	336	504	630	403	504	538	672	431	538
2/0 (67.4)	392	490	302	378	588	735	454	567	628	784	484	605
3/0 (85.0)	448	560	347	434	672	840	521	651	717	896	556	695
4/0 (107)	515	644	403	504	773	966	605	756	824	1 030	645	806
250 (127)	590	738	460	574	885	1 106	689	861	1 180	1 476	920	1 148
300 (152)	649	811	510	637	972	1 215	765	956	1 298	1 622	1 020	1 274
350 (177)	736	920	476	720	1 103	1 379	862	1 078	1 472	1 840	1 132	1 440
400 (203)	794	993	620	771	1 191	1 488	928	1 161	1 588	1 986	1 240	1 548
500 (253)	903	1 129	707	883	1 354	1 693	1 060	1 324	1 806	2 258	1 414	1 766
600 (304)	1 160	1 450	907	1 145	1 400	2 176	1 361	1 718	2 320	2 900	1 815	2 290
700 (355)	1 269	1 587	1 000	1 250	1 903	2 379	1 500	1 875	2 538	3 174	2 000	2 500
750 (380)	1 320	1 650	1 041	1 302	1 979	2 474	1 562	1 953	2 640	3 300	2 082	2 604
800 (405)	1 370	1 713	1 084	1 355	2 054	2 568	1 626	2 033	2 740	3 426	2 168	2 710
900 (456)	1 462	1 828	1 176	1 470	2 193	2 741	1 764	2 205	2 924	3 656	2 352	2 940
1 000 (507)	1 572	1 965	1 260	1 575	2 356	2 946	1 891	2 363	3 144	3 930	2 520	3 150
1 250 (633)	1 790	2 238	1 437	1 796	2 684	3 356	2 155	2 694	3 580	4 476	2 874	3 592

Table 8 – Cycling test currents for 75°C and 90°C connectors intended for paralleling conductors, A
Continued on Next Page

Table 8 – Cycling test currents for 75°C and 90°C connectors intended for paralleling conductors, A Continued

Conductor size, AWG or kcmil (mm ²)	Number and material of conductors											
	Two				Three				Four			
	Copper		Aluminum		Copper		Aluminum		Copper		Aluminum	
	75°C	90°C	75°C	90°C	75°C	90°C	75°C	90°C	75°C	90°C	75°C	90°C
1 500 (760)	1 975	2 469	1 596	1 995	2 961	3 701	2 395	2 993	3 950	4 938	3 192	3 990
1 750 (887)	2 150	2 688	1 764	2 205	3 226	4 032	2 647	3 308	4 300	5 376	3 528	4 410
2 000 (1 010)	2 328	2 910	1 932	2 415	3 491	4 364	2 899	3 623	4 656	5 820	3 864	4 830

Table 9 – Conductor stranding

(Clause 9.1.5.1)

Size of conductor to which connector is to be assembled		Number of strands, if stranded conductors		
		Copper		Aluminum
AWG or kcmil	(mm ²)	Class B	Class C	Class B
24 – 30	(0.20 – 0.05)	^a	–	–
22	(0.32)	7	–	–
20	(0.52)	10	–	–
18	(0.82)	16	–	–
16	(1.3)	26	–	–
14 – 2	(2.1 – 33.6)	7	19	7 ^b
1 – 4/0	(42.4 – 107)	19	37	19
250 – 500	(127 – 253)	37	61	37
600 – 1 000	(304 – 508)	61	91	61
1 250 – 1 500	(635 – 759)	91	127	91
1 750 – 2 000	(886 – 1 016)	127	271	127

^a Number of strands vary.

^b Aluminum 14 AWG (2.1 mm²) is not available.

Table 10 – Conductor materials

(Clause 9.1.5.1)

		AWG or kcmil (mm ²)	Test and control conductors shall be as follows:
Aluminum	Solid	12 (3.31) and larger	Aluminum wire stock for use as an electrical conductor
	Stranded ^a	12 – 3 (3.31 – 26.7)	Concentric or compressed Class B, aluminum designation 1350H-19, 1350H-16, or 1350H-26, and having an iron content of 0.4 percent maximum
		2 AWG – 1 000 (33.6 – 507)	i) Compact-stranded Class B, aluminum designation 1350H-19, and having an iron content of 0.4 percent maximum, or ii) Compressed Class B, aluminum designation 1350H-19, 1350H-16, or 1350H-26, and having an iron content of 0.25 percent maximum
		Larger than 1 000 (507)	Concentric or compressed Class B, aluminum designation 1350H-19, 1350H-16, or 1350H-26, and having an iron content of 0.25 percent maximum
Copper	Solid	30 – 16 (0.05 – 1.31)	Soft annealed, tinned or untinned
		14 (2.08) and larger	Soft annealed and untinned

Table 10 – Conductor materials Continued on Next Page

Table 10 – Conductor materials Continued

		AWG or kcmil (mm ²)	Test and control conductors shall be as follows:
	Stranded	30 – 16 (0.05 – 1.31)	Soft annealed, tinned or untinned
		14 (2.08) and larger	Soft annealed, tinned or untinned. The stranding shall be concentric or compressed Class B or concentric Class C
^a Conductors of AA-8000 series alloy conductor material shall not be used for testing purposes.			

Table 11 – Conductor insulation

(Clause 9.1.5.1)

		AWG or kcmil (mm ²)	Type of insulation
Aluminum	Solid	12 (3.31) and larger	THHN THW USE XHHW
	Stranded	All sizes	USE
Copper	Solid and stranded	30 – 24 (0.05 – 0.20)	Black thermoplastic at least 0.254 (0.010 in) thick
		22 – 16 (0.32 – 1.31)	Black thermoplastic at least 0.762 mm (0.030 in) thick
		14 (2.08) and larger	THHN THW USE XHHW

Table 12 – Test conductor length

(Clause 9.1.5.8)

Conductor size		Minimum conductor length ^a	
AWG or kcmil	(mm ²)	mm	(in)
30 – 8	(0.05 – 8.4)	203	(8)
6 – 3	(13.3 – 26.7)	305	(12)
2 – 500	(33.6 – 253)	457	(18)
Larger than 500	(Larger than 253)	660	(26)
^a The conductor length for the secureness test in the mechanical or static-heating sequence shall not be less than that specified in 9.3.2.1.			

Table 13 – Wire strip length

(Clauses 9.1.6.2, 9.1.6.3, and 10.15)

Connector type	Required wire strip length marking	
	Maximum strip length	Minimum strip length
Non-insulated	–	X ^{a,b,c}

Note: An X indicates marking is required.

^a Strip length shall be specified as a single – nominal – value if tested as specified in 9.1.6.2.

^b Strip length marking shall be optional if the connector is provided with an open end opposite the conductor insertion end through which the end of the conductor is visible after it is connected.

^c Strip length marking shall be optional if the connector is provided with an inspection hole opposite the conductor insertion end through which the end of the conductor is visible after it is connected.

Table 14 – Strip-length tolerances for conductors

(Clause 9.1.6.2)

Conductor size		Tolerance	
AWG or kcmil	(mm ²)	mm	(in)
30 – 14	(0.05 – 2.1)	± 0.8	(± 1/32)
12 – 10	(3.3 – 5.3)	± 1.2	(± 3/64)
8 – 250	(8.4 – 127)	± 1.6	(± 1/16)
300 – 2 000	(152 – 1 016)	± 3.2	(± 1/8)

Table 15 – Busbar dimensions

(Clauses 9.1.7.3 and 9.1.10.4)

Range of test current, A	Maximum cross-section, mm (in)	
	Copper	Aluminum
0 – 50	3.2 x 12.7 (1/8 x 1/2)	3.2 x 12.7 (1/8 x 1/2)
51 – 125	3.2 x 25 (1/8 x 1)	3.2 x 32 (1/8 x 1-1/4)
126 – 225	3.2 x 48 (1/8 x 1-7/8)	3.2 x 57 (1/8 x 2-1/4)
226 – 400	6.4 x 38 (1/4 x 1-1/2)	6.4 x 50 (1/4 x 2)
401 – 600	6.4 x 50 (1/4 x 2)	6.4 x 76 (1/4 x 3)
601 – 800	6.4 x 76 (1/4 x 3)	6.4 x 102 (1/4 x 4)
801 – 1 000	6.4 x 102 (1/4 x 4)	9.5 x 89 (3/8 x 3-1/2)
1 001 – 1 400	12.7 x 76 (1/2 x 3) or two 6.4 x 102 (1/4 x 4)	12.7 x 89 (1/2 x 3-1/2)
1 401 – 2 000	12.7 x 102 (1/2 x 4) or two 6.4 x 102 (1/4 x 4)	12.7 x 127 (1/2 x 5)
2 001 – 3 000	25 x 76 (1 x 3)	19 x 127 (3/4 x 5)
3 000 – 4 000	25 x 102 (1 x 4)	25 x 140 (1 x 5-1/2)
4 000 – 4 800	32 x 102 (1-1/4 x 4)	50 x 102 (2 x 4)

Table 16 – Tightening torque for screws

(Clauses 9.1.9.4 and 9.1.9.6)

Test conductor size installed in connector		Tightening torque, N·m (lbf·in)							
		Slotted head No. 10 and larger ^a				Hexagonal head – external drive socket wrench			
		Slot width – 1.2 mm (0.047 in) or less and slot length – 6.4 mm (1/4 in) or less		Slot width – over 1.2 mm (0.047 in) or slot length – over 6.4 mm (1/4 in)		Split-bolt connectors		Other connectors	
AWG or kcmil	(mm ²)	A	B	A	B	A	B	A	B
30 – 10	(0.05 – 5.3)	1.7 (15)	2.3 (20)	2.8 (25)	4.0 (35)	7.3 (65)	9.0 (80)	6.8 (60)	8.5 (75)
8	(8.4)	2.3 (20)	2.8 (25)	3.4 (30)	4.5 (40)	7.3 (65)	9.0 (80)	6.8 (60)	8.5 (75)
6 – 4	(13.2 – 21.2)	2.8 (25)	4.0 (35)	4.0 (35)	5.1 (45)	15.3 (135)	18.6 (165)	10.2 (90)	12.4 (110)
3	(26.7)	2.8 (25)	4.0 (35)	4.5 (40)	5.6 (50)	25.4 (225)	31.1 (275)	14.1 (125)	16.9 (150)
2	(33.6)	3.4 (30)	4.5 (40)	4.5 (40)	5.6 (50)	25.4 (225)	31.1 (275)	14.1 (125)	16.9 (150)
1	(42.4)	–	–	4.5 (40)	5.6 (50)	25.4 (225)	31.1 (275)	14.1 (125)	16.9 (150)
1/0 – 2/0	(53.5 – 67.4)	–	–	4.5 (40)	5.6 (50)	35.6 (315)	43.5 (385)	16.9 (150)	20.3 (180)
3/0 – 4/0	(85.0 – 107.2)	–	–	4.5 (40)	5.6 (50)	45.2 (400)	56.5 (500)	22.6 (200)	28.2 (250)
250 – 350	(127 – 177)	–	–	4.5 (40)	5.6 (50)	62.1 (550)	73.4 (650)	28.2 (250)	36.7 (325)
400	(203)	–	–	4.5 (40)	5.6 (50)	76.3 (675)	93.2 (825)	28.2 (250)	36.7 (325)
500	(253)	–	–	4.5 (40)	5.6 (50)	76.3 (675)	93.2 (825)	33.9 (300)	42.4 (375)
600 – 750	(304 – 380)	–	–	4.5 (40)	5.6 (50)	90.4 (800)	113.0(1000)	33.9 (300)	42.4 (375)
800 – 1000	(406 – 508)	–	–	4.5 (40)	5.6 (50)	111.7 (900)	124.3(1100)	45.2 (400)	56.5 (500)
1250 – 2000	(635 – 1010)	–	–	–	–	111.7 (900)	124.3(1100)	56.5 (500)	67.8 (600)

^a For values of slot width or length not corresponding to those specified, select the largest torque value associated with the conductor size. Slot width is the nominal design value. Slot length shall be measured at the bottom of the slot.

Table 17 – Tightening torque for slotted head screws smaller than No. 10 intended for use with 8 AWG (8.4 mm²) or smaller conductors

(Clauses 9.1.9.4 and 9.1.9.6)

Slot length of screw ^a		Tightening torque, N·m (lbf·in)			
		Slot width of screw smaller than 1.2 mm (0.047 in) ^b		Slot width of screw 1.2 mm (0.047 in) and larger ^b	
mm	(in)	A	B	A	B
Less than 4	(Less than 5/32)	0.68 (6)	0.79 (7)	0.79 (7)	1.0 (9)
4	(5/32)	0.68 (6)	0.79 (7)	1.1 (10)	1.4 (12)
4.8	(3/16)	0.68 (6)	0.79 (7)	1.1 (10)	1.4 (12)
5.6	(7/32)	0.68 (6)	0.79 (7)	1.1 (10)	1.4 (12)
6.4	(1/4)	0.79 (7)	1.0 (9)	1.1 (10)	1.4 (12)
7.1	(9/32)	–	–	1.4 (12)	1.7 (15)
Above 7.1	(Above 9/32)	–	–	1.8 (16)	2.3 (20)

^a For slot lengths of intermediate values, select torques pertaining to next shorter slot lengths. Also, see 9.1.9.6 for screws with multiple tightening means. Slot length shall be measured at the bottom of the slot.

^b Slot width is the nominal design value.

Table 18 – Tightening torque for screws with recessed allen or square drives

(Clauses 9.1.9.4 and 9.1.9.6)

Socket width across flats ^a		Tightening torque, N·m (lbf·in)			
mm	(in)	A		B	
3.2	(1/8)	4.0	(35)	5.1	(45)
4.0	(5/32)	9.0	(80)	11.3	(100)
4.8	(3/16)	11.3	(100)	13.6	(120)
5.6	(7/32)	13.6	(120)	16.9	(150)
6.4	(1/4)	16.9	(150)	22.6	(200)
7.9	(5/16)	25.4	(225)	31.1	(275)
9.5	(3/8)	33.9	(300)	42.4	(375)
12.7	(1/2)	45.2	(400)	56.5	(500)
14.3	(9/16)	56.5	(500)	67.8	(600)

^a See 9.1.9.6 for screws with multiple tightening means.

Table 19 – Tightening torque for connecting hardware

(Clause 9.1.10.2)

Screw or bolt size		Tightening torque	
Metric	SAE	N·m	(lbf·ft)
–	No. 8 or smaller	2	(1.5)
–	No.10	3	(2.0)
M6	1/4	8	(6)
–	5/16	15	(11)
M10	3/8	26	(19)
–	7/16	41	(30)
M12	1/2	54	(40)
–	9/16, 5/8 or larger	75	(55)

Table 20 – Flattening force

(Clause 9.1.10.3)

Bolt size		Force, minimum	
Metric	SAE	N	(lb)
M6	1/4	3 560	(800)
–	5/16	4 450	(1 000)
M10	3/8	6 230	(1 400)
M12	7/16, 1/2	12 015	(2 700)
–	9/16, 5/8 or larger	15 130	(3 400)

Table 21 – Secureness test values

(Clauses 9.3.2.1)

Size of conductor		Diameter of bushing hole ^a		Height		Mass			
AWG or kcmil	(mm ²)	mm	(in)	mm	(in)	Copper		Aluminum	
						kg	(lb)	kg	(lb)
18	(0.82)	6.4	(1/4)	260 ^b	(10-1/4) ^b	0.45	(1)	—	—
16	(1.3)	6.4	(1/4)	260 ^b	(10-1/4) ^b	0.45	(1)	—	—
14	(2.1)	9.5	(3/8)	279 ^b	(11) ^b	0.68	(1.5)	—	—
12	(3.3)	9.5	(3/8)	279 ^b	(11) ^b	0.9	(2)	0.7	(1.5)
10	(5.3)	9.5	(3/8)	279 ^b	(11) ^b	1.4	(3)	0.7	(1.5)
8	(8.4)	9.5	(3/8)	279 ^b	(11) ^b	2.0	(4.5)	1.4	(3)
6	(13.3)	12.7	(1/2)	298 ^b	(11-3/4) ^b	2.9	(6.5)	4.0	(9)
4	(21.2)	12.7	(1/2)	298 ^b	(11-3/4) ^b	4.5	(10)	4.5	(10)
3	(26.7)	14.3	(9/16)	318	(12-1/2)	5.9	(13)	5.9	(13)
2	(33.6)	14.3	(9/16)	318	(12-1/2)	6.8	(15)	6.8	(15)
1	(42.4)	15.8	(5/8)	343	(13-12)	8.6	(19)	8.6	(19)
1/0	(53.5)	15.8	(5/8)	343	(13-1/2)	9.5	(21)	9.5	(21)
2/0	(67.4)	19.1	(3/4)	368	(14-1/2)	10.4	(23)	10.4	(23)
3/0	(85.0)	19.1	(3/4)	368	(14-1/2)	14.0	(31)	13.6	(30)
4/0	(107)	19.1	(3/4)	368	(14-1/2)	14.0	(31)	13.6	(30)
250	(127)	22.2	(7/8)	406	(16)	14.0	(31)	13.6	(30)
300	(156)	22.2	(7/8)	406	(16)	15.0	(33)	15.4	(34)
350	(177)	25.4	(1)	432	(17)	16.8	(37)	17.2	(38)
400	(203)	25.4	(1)	432	(17)	16.8	(37)	17.2	(38)
500	(253)	28.6	(1-1/8)	464	(18-1/4)	20.0	(44)	20.4	(45)
600	(304)	28.6	(1-1/8)	464	(18-1/4)	20.0	(44)	20.4	(45)
700	(354)	31.8	(1-1/4)	495	(19-1/2)	22.7	(50)	21.8	(48)
750	(380)	31.8	(1-1/4)	495	(19-1/2)	22.7	(50)	24.5	(54)
800	(406)	34.9	(1-3/8)	540	(21-1/4)	25.0	(55)	24.5	(54)
900	(456)	34.9	(1-3/8)	540	(21-1/4)	25.0	(55)	25.0	(55)
1 000	(508)	38.1	(1-1/2)	565	(22-1/4)	25.0	(55)	25.0	(55)
1 250	(635)	44.5	(1-3/4)	660	(26)	34.0	(75)	34.0	(75)
1 500	(759)	50.8	(2)	711	(28)	41.0	(90)	41.0	(90)
1 750	(886)	54.0	(2-1/8)	762	(30)	45.0	(99)	45.0	(100)
2 000	(1 010)	54.0	(2-1/8)	762	(30)	54.0	(119)	54.4	(120)

^a If a hole with the diameter given is insufficient to accommodate the conductor without binding, a bushing having a hole of slightly large diameter shall be allowed to be used.

^b For 12 – 4 AWG (3.3 – 21.2 mm²) aluminum conductor, used 318 mm (12-1/2 in).

Table 22 – Pullout test values

(Clause 9.3.4.1)

Size of conductor		Pullout force, N (lb)			
AWG or kcmil	(mm ²)	Copper		Aluminum	
30	(0.05)	2.2	(1-1/2)	–	–
28	(0.08)	4.5	(1)	–	–
26	(0.13)	8.9	(2)	–	–
24	(0.20)	13.4	(3)	–	–
22	(0.32)	20	(4.5)	–	–
20	(0.52)	30	(6.75)	–	–
18	(0.82)	30	(6.75)	–	–
16	(1.3)	40	(9)	–	–
14	(2.1)	50	(11.5)	–	–
12	(3.3)	60	(13.5)	44	(10)
10	(5.3)	80	(18.0)	44	(10)
8	(8.4)	90	(20.5)	44	(10)
6	(13.3)	94	(21)	124	(28)
4	(21.2)	133	(30)	160	(36)
3	(26.7)	156	(35)	187	(42)
2	(33.6)	186	(42)	222	(50)
1	(42.4)	236	(53)	271	(61)
1/0	(53.5)	285	(64)	320	(72)
2/0	(67.4)	285	(64)	347	(78)
3/0	(85.0)	351	(79)	432	(97)
4/0	(107)	427	(96)	516	(116)
250	(127)	427	(96)	516	(116)
300	(156)	441	(99)	516	(116)
350	(177)	503	(113)	574	(129)
400	(203)	503	(113)	574	(129)
500	(253)	578	(130)	685	(154)
600	(304)	578	(130)	685	(154)
700	(355)	645	(145)	796	(179)
750	(380)	690	(155)	796	(179)
800	(405)	690	(155)	796	(179)
900	(456)	702	(158)	805	(181)
1000	(507)	778	(175)	885	(199)
1250	(633)	965	(217)	1 116	(251)
1500	(760)	1 174	(264)	1 343	(302)
1750	(877)	1 347	(303)	1 521	(342)
2000	(1010)	1 521	(342)	1 699	(382)

Figure 1 – Method for attaching thermocouples to stranded aluminum control conductors used for current-cycling tests




Figure 2 – Method for mounting tangless type equipment wiring terminals





Figure 4 – Secureness test setup



SM1120

ANNEX A – Informative References

(Informative)

(Clause 2.2.1)

The following references contain information on conductors and materials in this Standard. At the time of publication, the editions indicated were valid.

UL Standards

ASTM* Standards

B 8-99

Standard Specification for Concentric-Lay-Stranded Copper Conductors, Hard, Medium-Hard, or Soft

B 154-95

Standard Test for Method for Mercurous Nitrate Test for Copper and Copper Alloys

B172-95

Standard Specification for Rope-Lay-Stranded Copper Conductors Having Bunch-Stranded Members, for Electrical Conductors

B 173-95

Standard Specification for Rope-Lay-Stranded Copper Conductors Having Concentric-Stranded Members, for Electrical Conductors

B 174-95

Standard Specification for Bunch-Stranded Copper Conductors for Electrical Conductors

B 230/B 230M-99

Standard Specification for Aluminum 1350-H19 Wire for Electrical Purposes

B 231/B 231M-99

Standard Specification for Concentric-Lay-Stranded Aluminum 1350 Conductors

B 400-94

Standard Specification for Compact Round Concentric-Lay-Stranded Aluminum 1350 Conductors

B 496-99

Standard Specification for Compact Round Concentric-Lay-Stranded Copper Conductors

B 609/B 609M-99

Standard Specification for Aluminum 1350 Round Wire, Annealed and Intermediate Tempers, for Electrical Purposes

B 638-99

Standard Test Method for Tensile Properties of Plastics

IEC† Standards

IEC 60228 (1978-01)
Conductors of Insulated Cables

IEC 60228A (1993-01)
Conductors of Insulated Cables - Amendment No. 1 .

*American Society for Testing and Materials.

†International Electrotechnical Commission.

ANNEX B – Examples

(Informative)

(Clauses 7.1.4, 8.3.2, and 8.3.3)

B.1 Examples from Clause 7.1.4

B.1.1 A setscrew type equipment wiring terminal is rated 4 AWG - 250 kcmil CU/AL. The conductor sizes required for current-cycling testing are 250 kcmil CU and 250 kcmil AL. In accordance with Clause 7.1.4, the current-cycling test using copper conductor need not be conducted because the size of the aluminum conductor to be current-cycling tested is not smaller than the size of the copper conductor.

B.1.2 A setscrew type equipment wiring terminal is rated 4 AWG – 250 kcmil CU, 4 – 1/0 AWG AL. The conductor sizes required for current-cycling testing are 250 kcmil CU and 1/0 AWG AL. As the size of the aluminum conductor to be tested is smaller than the size of the copper conductor, Clause 7.1.4 does not apply and the current-cycling test needs to be conducted for both copper and aluminum conductors.

B.2 Example from Clause 8.3.2 (ampere-rated, non-parallel)

For an equipment wiring terminal rated 200 amperes, 250 kcmil (127 mm²) through 1/0 AWG (53.5 mm²), AL-CU, the required conductor sizes selected for the current-cycling, static-heating sequence, and mechanical sequence would be as follows:

Conductor size		Copper conductor ^a	Aluminum conductor
AWG/kcmil	(mm ²)		
250	(127)	Mechanical sequence	Static-heating sequence/current-cycling
4/0	(107.2)	–	–
3/0	(85)	Static-heating sequence/current-cycling ^b	–
2/0	(67.3)	–	–
1/0	(53.5)	Mechanical sequence	Mechanical sequence

^a Also applicable for an aluminum-bodied equipment wiring terminal rated for copper wire only.

^b Current cycling may be waived; see 7.1.4 and 8.2.1 – 8.2.4.

The following example is for an equipment wiring terminal rated 200 amperes 4/0 AWG to 1/0 AWG (107.2 to 53.5 mm²) rated CU only and copper-bodied.

Conductor size		Copper conductor
AWG	(mm ²)	
4/0	(107.2)	Mechanical sequence
3/0	(85)	Static-heating sequence
2/0	(67.3)	–
1/0	(53.5)	Mechanical sequence

B.3 Example from Clause 8.3.3 (ampere-rated, both parallel and non-parallel)

For an equipment wiring terminal rated 400 amperes with a conductor range of a single 700 kcmil – 2/0 AWG (355 – 67.4 mm²) and a parallel range of (2) 250 – 1/0 AWG (127 – 53.5 mm²) rated CU-AL, the required tests are as follows:

Number of conductors	Conductor size		Conductor type	
	AWG/kcmil	(mm ²)	Copper ^a	Aluminum
1	700	(355)	Mechanical sequence	Static-heating sequence/ current-cycling
1	600	(304)	Static-heating sequence/ current-cycling ^b	–
1	2/0	(67.4)	Mechanical sequence	Mechanical sequence
2	250	(127)	Mechanical sequence	Static-heating sequence/ current-cycling
2	3/0	(85)	Static-heating sequence/ current-cycling ^b	–
2	1/0	(53.5)	Mechanical sequence	Mechanical sequence

^a Also applicable for an aluminum-bodied connector rated for copper wire only.

^b Current cycling may be waived; see 7.1.4 and 8.2.1 – 8.2.4.

ANNEX C – Stability Factor Calculation

(Informative)

(Clause 7.2.4)

Example of stability factor calculation:

Cycle number	Temperature °C		d	S _i
	Specimen	Control conductor		
25	130	135	-5	-6.5
50	131	136	-5	-6.5
75	133	135	-2	-3.5
100	136	135	1	-0.5
125	136	135	1	-0.5
175	138	135	3	1.5
225	139	136	3	1.5
275	138	135	3	1.5
350	141	136	5	3.5
425	142	136	6	4.5
500	142	136	6	4.5
Sum 16				
Average (D) = +1.5				

No Text on This Page

ANNEX D – Marking Locations Guide

(Informative)

(Clause 10.1)

Clause	Subject ^{a, d}	Location options ^{a, b}
	General	
10.3	Manufacturer's name or trademark	A
10.3	Catalog number	A ^c
10.3, 10.5, 10.9, 10.10	Conductor size or range of sizes	A ^c , C
10.31	For Use with Specific Equipment	B
	Conductor type and connector ratings	
10.6	Conductor material, CU	A, B
10.7, 10.8	Conductor material, AL, AL-CU, CC_CU, etc.	A, E
10.16, 10.17, 10.18, 10.19	Equipment wiring terminal rating, 75, 90, CU7, AL9CU, etc.	A, E
10.20	Intermixing, (intermixed – dry locations)	A, E
	Stranding and other conductor types	
10.13, 10.14	Solid and/or stranded	A, B
10.12	Other conductor classes and stranding	A, B
10.25, 10.26	Metric conductors	A, B
10.30	Compact copper	A, B
	Miscellaneous ratings	
10.22	Assigned tightening torque	A, B
10.23	Assigned ampere rating	A, E
	Installation and assembly instructions	
10.15	Proper assembly procedure for connector	
a)	– Specific tool usage	A, B
b)	– Multiple crimping	A, B, C
c)	– Strip length	A, B, C, D
d)	– Preliminary preparation	B
10.21	Dished washer and hardware assembly instructions	B
10.11	Rearrangement/adjustment instructions to adapt to different sizes	A, B
	Unit container and information sheet	
10.24	Unit container / information sheet	B
	– Manufacturer's name	
	– Catalog number or equivalent	
10.28, 10.29	Identifying number	B
^a These are a brief summary of marking requirements. For complete details, see the specific clause. ^b Marking locations are coded as follows: A. On the equipment wiring terminal. B. On the unit container or information sheet within the unit container. Markings are not to be divided between unit container and information sheet, see 10.27. C. On or with the tool. D. On the insulator.		

Table Continued on Next Page

Table Continued

Clause	Subject ^{a, d}	Location options ^{a, b}
E. May be on the unit container or on an information sheet packed in the unit container for a connector used with 6 AWG (13.3 mm ²) or smaller conductors.		
^c For small devices, may be replaced with an identifying symbol. See 10.4.		
^d See 10.2. Markings applicable to an equipment wiring terminal which are not an integral part of equipment. Refer to end product standard for markings on equipment wiring terminals which are integral to the equipment.		